

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	UKPN2002	Question Number	6
Question date	1 September 2011	Answer date	6 September 2011
Submission section question relates to			
Topic	Protection		
Question	Do the directional relay systems you propose to trial provide additional functionality or are they simply to overcome the 75% setting limit?		
Notes on question			
Answer	In addition to overcoming the 75% DOC setting limit, the modern protection relays will be used to support adaptive protection and intertripping solutions using Generic Object Oriented Substation Event (GOOSE). Moreover, the modern protection relays will be used to demonstrate interoperability with other smart devices and smart applications.		
Attachments			
Verbal Clarifications (Consultants			

)	
---	--