

CUSC – Section 4

4.1.1 Application

The provisions of this Paragraph 4.1 shall apply to **Users** which are **Generators** in respect of **Generating Units** from which they are required to provide the **Mandatory Ancillary Services** to **NGC** in accordance with the **Grid Code** (for the avoidance of doubt, as determined by any direction in force from time to time and issued by the **Authority** relieving any such **User** from the obligation under its **Licence** to comply with such part or parts of the **Grid Code** or any **Distribution Code** or, in the case of **NGC**, the **Transmission Licence**, as may be specified in such direction).

In respect of **Generating Unit(s)** which are required to provide **Mandatory Ancillary Services** to **NGC** in accordance with the **Grid Code** and which are not registered as **BM Unit(s)**, the **Mandatory Services Agreement** shall detail how the provisions of Section 4 and Schedule 3 of the **CUSC** which refer to **BM Unit(s)** shall (notwithstanding such **Generating Unit(s)** are not registered as **BM Unit(s)**) apply.

CUSC – SCHEDULE 3 – PART I

2.8 Notwithstanding the foregoing provisions of this Paragraph 2, and without prejudice to Paragraph 5, **NGC** shall only be obliged to amend or conclude any **Mandatory Services Agreement** with regard to any **Generating Unit** if:-

- (a) the leading or lagging **Reactive Power** capability required of the **Generating Unit** in accordance with **Grid Code CC 6.3.2** (or, where the **Generating Unit** is **Derogated Plant** the level to which, it has been **Derogated**) is 15Mvar or more (measured at the **Commercial Boundary**); and
- (b) there exists in relation to that **Generating Unit** metering facilities meeting the requirements of Appendix 4.