

LCNF Full Submission

Supplementary Answer Form

DNO Name:	Electricity North West Limited	Question Number:	ENWL032
Question Date:	21 Sept 2010	Answer Date:	24 Sept 2010
Question Topic:		Box 4	

Original Question No:		Original Answer Date:	
Original Question:			
Original Answer:			

Question:	<p>Please provide an estimate of the number of customers who will be affected by planned shutdowns required to install the new equipment. Please also provide the potential duration of the outages. Please indicate whether similar interruptions would be required in order to roll-out the project if the trial was successful. As per the Governance Document, please set out whether you would withdraw the request for Second Tier Funding in the event that Ofgem would not support the change to the regulatory arrangements requested.</p>
------------------	---

Answer:	<p>We calculate the number who will be affected by planned shutdowns required to install the new equipment to be 4700.</p> <p>The potential average duration of the outages is estimated to be 4 hours.</p> <p>It is anticipated that similar interruptions would be required in order to roll-out the Project if the trial was successful.</p> <p>Electricity North West will not withdraw its request for Second Tier Funding in the event that Ofgem would not support the change to the regulatory arrangements requested. However, we will review the viability of the</p>
----------------	---

	Project following Ofgem's response to our request for funding.
--	--

Attachments:	None.
---------------------	-------