

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	WPDT2003	Question Number	3
Question date	25 August 2011	Answer date	30 August 2011
Submission section question relates to	Appendix F		
Topic	Carbon		
Question	How was the average aggregated size of 60kW arrived at?		
Notes on question			
Answer	This figure was derived from the estimation of 30 properties per network connected substation connecting a level of 2kW micro-generation each, totalling 60kW.		

Attachments	
Verbal Clarifications (Consultants)	