

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	WPDT2003	Question Number	19
Question date	13/09/11	Answer date	20/09/11
Submission section question relates to	Section 4b		
Topic			
Question	How would you deal with a circumstance where not all customers on a substation want the BRISTOL solution?		
Notes on question			
Answer	<p>The BRISTOL solution does not require all customers to have battery storage installed. BRISTOL it is a modular solution that will allow increasing numbers of customers to connect microgeneration and other Low Carbon Technologies to the network when its headroom has been reached.</p> <p>In situations where customers requested further connections which would cause the distribution network to operate beyond its limits, who do not wish to have a BRISTOL solution the appropriate conventional network reinforcement would be used to complement the network controlled battery storage on the same substation.</p>		

Attachments	
Verbal Clarifications (Consultants)	