

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	WPDT2003	Question Number	10
Question date	13/09/11	Answer date	20/09/11
Submission section question relates to	Section 8		
Topic	2 hour test		
Question	Please can you say a little more about the assessment of the performance of the pv panels if the AC power is disconnected. Will the 2-hour test (page 45) be conducted regardless of the level of sunshine?		
Notes on question			
Answer	<p>The focus of the power outage test is the DC network, batteries and customer behaviour during the outage. The operation of the PV panels may influence customers behaviours, however the test is not specifically focussed on the performance of the PV panels.</p> <p>The LV Connection Manager will record the output from the PV, displaying the information to customers.</p> <p>The trials will be scheduled at different times of the day with different weather conditions and battery capacities to maximise the learning. Selected customers will be asked to undergo this test once during the trial.</p>		
Attachments			

Verbal Clarifications (Consultants)	
---	--