

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	ENWLT2003	Question Number	27
Question date	6 September 2011	Answer date	13 September 2011
Submission section question relates to	3 (Page 11)		
Topic	Project Business Case		
Question	Do the costs of the scale-up included upgrading from 400A to 630A switchgear?		
Notes on question	n/a		
Answer	No – this switchgear upgrade was not required. The methodology applied to determine the network costs of the C ₂ C Solution for the Trial, and then to scale these costs to ENWL and then to GB, is based on the ten case studies reviewed in conjunction with PB. The ten case studies did not include the upgrading of HV switchgear at a primary substation and therefore the cost of primary switchgear changes are not included in the scaling methodology.		
Attachments	None.		
Verbal Clarifications (Consultants)	None.		