

*LCN Fund Full Submission*

# *Supplementary Answer Form*

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	ENWLT2003	Question Number	13
Question date	1 September 2011	Answer date	6 September 2011
Submission section question relates to	4		
Topic	Evaluation Criteria		
Question	How confident are you in your prediction of delivering 1800 C2C customers in the Trial area by 2035?		
Notes on question	n/a		
Answer	<p>By 2035 we fully expect that demand side and generation side response provision will be the norm and its provision will be codified within DCUSA and the National Terms of Connection. What we do not know – but which the Trial will begin to answer - is whether we will have 180 or 1800 or 3600 customers providing the required response for the named circuits within the Trial area.</p> <p>Our estimate of requiring 1800 customers was based on 0.3MW of response per customer (over 180 rings and 10 I&amp;C C<sub>2</sub>C customers per ring). More or less customers may be required if the economic level of demand response is lower or higher than 0.3MW.</p>		
Attachments	None.		

Verbal Clarifications  (Consultants )	None.
---	-------