

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SPT 2003	Question Number	16
Question date	13/09/2011	Answer date	20/09/2011
Submission section question relates to	Page 5 of submission		
Topic	Safety		
Question	Have you considered safety issues for the trial? Are you developing a Safety Case for the proposed Method(s) as part of the project that can be used if/when the Method become business as usual?		
Notes on question			
Answer	<p>Yes, the safety issues of the trial have been considered and the majority of working methods for the project activities are already covered by the existing Scottish Power Safety Rules, Safety Procedures and Safety Management System.</p> <p>The only area identified that may need a possible additional procedure, is the monitoring equipment installation on certain apparatus types. To avoid the need to isolate the apparatus and cause potential interruption of supplies, a procedure is being considered to ensure low-risk safe working whilst in close proximity to live apparatus.</p> <p>Discussions are currently ongoing with Scottish Power Safety department to evaluate the need for a separate procedure. Any new procedure produced would become part of the 'Business as Usual' safety documents suite.</p>		

Attachments	
Verbal Clarifications (Consultants)	