

*LCN Fund Full Submission*

## *Supplementary Answer Form*

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SPT 2003	Question Number	3
Question date	25/08/2011	Answer date	30/08/2011
Submission section question relates to	Proforma Section 2		
Topic	St Andrews trial site		
Question	How confident are you the University's requirements for maximum demand will increase from 1.9MVA to 5MVA? Will the University have exhausted all low carbon options before reaching 5MVA?		
Notes on question			
Answer	<p>From our initial discussions with St Andrews University, they have already undertaken a number of energy efficiency and low carbon initiatives such as voltage optimisation on a number of buildings and the installation of a CHP unit. The university has been praised for its commitment to a green agenda and energy saving initiatives. The connection of the windfarm will also help to offset their energy costs and carbon impact of the University estate.</p> <p>The upper value of the University's demand is based on previous discussion with the University in terms of their expansion plans and we are unsure at this time on future initiatives that they are planning to reduce their maximum demand.</p>		

Attachments	
Verbal Clarifications  (Consultants )	