Proposed Additional areas to be assessed by Lloyds Register following publication of Revised Document -Based on Draft 6 -June 2011

Following the proposed publication of the revised MAMCoP in late 2011, Lloyds Register is proposing to include the following additional areas shown below within surveillance and re-accreditation cycles planned for late 2011/2012. For any new organisations seeking accreditation following publication of the revised document, the changes shown below shall form part of the initial assessment

| 3.2.1 | Scope 1.6 | Category 1 & 2 Category 3A –LP meters <40scmh Category 3B- LP meters >40 scmh Category 4A –MP meters >16 barg Category 4B –MP meters 16 -85barg Define which categories the MAM seeks to achieve and compare against current MAM asset register. New certificates will be issued defining the new categories of accreditation and will have a three year validity period. | |
|-------|------------------------|--|--|
| 3.2.2 | Responsibilities 3.2.1 | Engineer or manager qualification level IGEM membership number Other institution Detail conformance with requirement | |
| 3.2.5 | Responsibilities 3.2.5 | Documented audit procedure in place Competency of auditors checked Completed site audit documentation available Process for recording/closing out non-conformances <i>Record document or procedure reference and detail any audit findings</i> | |

Code of Practice for Gas Meter Asset Managers Proposed Additional areas to be assessed by Lloyds Register following publication of Revised Document –Based on Draft 6 -June 2011

| 3.2.8 | Maintenance 12.1 | A maintenance review should be undertaken every 3 years or upon a major change of circumstances | |
|-------|--------------------------|---|--|
| | | Record date of last maintenance review and any changes implemented as a result of the review | |
| 3.3.1 | Maintenance 12.2.2. | Maintenance records to include the settings of pressure protection devices | |
| | | Review maintenance records for compliance | |
| 3.3.2 | Installation Performance | Procedure for sample testing of domestic meters required | |
| | Functionality Monitoring | Sample size to be statistically robust (outlined in BS6002-1) | |
| | 17.5.2 | Records of sampling to be available during audit | |
| | | Document meter sampling procedure reference and detail numbers of meters sampled and any significant findings | |