

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SSET205	Question Number	SSES010
Question date	23/08/2012	Answer date	28/08/2012
Submission section question relates to	2		
Topic	Project Readiness		
Question	Please explain the extent to which discussions have taken place with charger manufacturers exploring the feasibility of implementing switching technology within these devices.		
Notes on question			
Answer	To date work has been based on the standard IEC 62196 and how this can be used to integrate the Technology as the design should be independent of any particular manufacturer. Discussions will take place during the project as indicated in the project plan. The technology has been designed so that it can be installed in series with a charging socket rather than integrated with it if required. Thus, integration with the charging point is not essential. This also provides the flexibility to allow the Technology to control other loads such as heat pumps.		
Attachments			

Verbal Clarifications (Consultants)	
--	--