

*LCN Fund Full Submission*

# *Supplementary Answer Form*

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SSET205	Question Number	SSES024
Question date	02-October-2012	Answer date	04-Oct-2012
Submission section question relates to	8		
Topic	Customer Impact.		
Question	You note that you expect the PLC monitor control can be installed live. When will you be able to confirm that this is the case? If the PLC cannot be installed live, please outline how many interruptions will result and how long will they last.		
Notes on question			
Answer	<p>Whilst we have demonstrated in previous PLC projects that it is possible to install the equipment without an outage to customers (eg breaching onto a live cable using live-working techniques), it cannot be guaranteed that every potential site will be suitable for such an installation method without a survey of the substation in question.</p> <p>As such, confirmation of necessary outages, (if all available live-working methods are unsuitable for use) at each location will have to be determined on a case-by-case basis, as cluster locations are identified.</p>		
Attachments			
Verbal Clarifications (Consultants )			