

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SSET205	Question Number	SSES023
Question date	02-October-2012	Answer date	04-Oct-2012
Submission section question relates to	8		
Topic	Customer Impact.		
Question	Please confirm that there are no planned interruptions for customers who are not involved in the trial.		
Notes on question			
Answer	<p>It is the ultimate intention of the trial that there will be no disruption to customers as part of the installation of the solution; in order to achieve this different techniques will be assessed for installation, though recognising that tailoring will be required to suit different applications (eg. pole-mounted substations/ground mounted open LV boards/ground mounted closed LV boards).</p> <p>As such, currently there are no planned interruptions for any customers not having equipment installed, however, there is a possibility that a brief (planned) outage would be required to install the PLC at the substation in some, specific circumstances.</p>		
Attachments			
Verbal Clarifications (Consultants)			