

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SSET205	Question Number	SSES019
Question date	20-September-2012	Answer date	24-09-2012
Submission section question relates to	2		
Topic	Project Description		
Question	Please confirm whether the Esprit Technology monitors voltage at the remote end of LV feeders.		
Notes on question			
Answer	<p>The Esprit Technology has the capability to measure voltage at the point of the Technology's installation at the customer's connection, regardless of where on the feeder it is located. As such if the Technology is installed in a premises at the extreme end of a feeder the voltage at the end of the feeder can be accurately measured. If however, the technology is installed at a connection part way down a feeder, then the data provided can be used to make a reasonable estimate of the voltage at the remote end. Any measurements taken can be transmitted to a data-logger for future retrieval and analysis if required.</p>		
Attachments			
Verbal Clarifications (Consultants)			