

*LCN Fund Full Submission*

# *Supplementary Answer Form*

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	WPD-T2-04	Question Number	WPD015
Question date	04.09.2012	Answer date	07.09.2012
Submission section question relates to	2		
Topic	Project Description		
Question	Are all of the Fault Mitigation Technologies 'fail safe' – a requirement that was established during consideration of the use of IS Limiters?		
Notes on question			
Answer	<p>Yes, all the Fault Level Mitigation Technologies that have, and will be, considered will 'fail safe'. The request for information relating to Fault Level Mitigation Technologies was explicit in its requirement for detail on the health and safety requirements of the technology.</p> <p>IS limiters have not been, and will not be, considered for use in this project. Where an IS limiter is understood to be a device that limits the Fault Level through the use of an expulsion fuse.</p>		
Attachments			
Verbal Clarifications (Consultants )			