

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	WPD-T2-04	Question Number	WPD004
Question date	23.08.2012	Answer date	30.08.2012
Submission section question relates to	Appendix E and K		
Topic	Risk Register and Test Report		
Question	Why is it considered a risk that the Method Beta technology will not be available, if it has already been identified?		
Notes on question			
Answer	<p>The product developed under the Tier-1 LCNF Project, Active Fault Level Management Scheme, between S&C Electric and Outram Research Limited has been successfully tested. However, neither company is a project partner and this product is not the only possible provider of such technology.</p> <p>There can be no certainty of supply of the developed product or of another product, but through the LCNF Tier-1 project WPD has significantly de-risked this element and the chance of a product being produced is high.</p>		
Attachments			
Verbal Clarifications (Consultants)			