


LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	WPD-T2-04	Question Number	WPD020
Question date	06.09.2012	Answer date	10.09.2012
Submission section question relates to	2		
Topic	Project Description		
Question	Please clarify whether customer interruptions will be required to install the Method Beta equipment, and explain whether it is anticipated that customers will experience any supply quality issues as a result of the Method Beta tests.		
Notes on question			
Answer	<p>Planned customer interruptions are not required at any part of the process to install equipment as part of Method Beta.</p> <p>Laboratory test results have indicated that customers will not experience any supply quality issues as a result of Method Beta. Further evidence is provided in the attached document.</p>		
Attachments	 Implementation of an Active Fault Level Ma		
Verbal Clarifications (Consultants)			