

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SPD2004	Question Number	SPD021
Question date	06/09/2012	Answer date	10/09/2012
Submission section question relates to	Full Submission Workbook		
Topic	Project Business Case		
Question	For Case Studies 1-4 can SPD confirm whether the method costs include the incremental costs of the ANM solution (to the generator), and can they indicate the split of distribution connection costs and ANM costs?		
Notes on question			
Answer	<p>SPD can confirm that the method costs are included the incremental costs of the ANM solution to the generator. The incremental cost of adding a generator to an ANM scheme will relate to communication equipment and the necessary interfaces with the generators own equipment. There will also be some commissioning costs involved. It is considered however that these cost will be small compared to the wider connection and development of a particular generation project.</p> <p>The ANM does require some enabling works at the GSP in case studies 1-3 and one of the objectives of the project is to understand how these costs should be met, i.e. if it should be socialised, and develop learning about benefit accrued etc.</p>		
Attachments			

Verbal Clarifications (Consultants)	
---	--