

Transmission Planning and Delivery in PJM: Process, Market Drivers and Trends


**International Experience in Transmission Planning and Delivery
January 11-12, 2013 Imperial College
London, UK**

Paul M. Sotkiewicz, Ph.D.
Chief Economist
PJM Interconnection



PJM Broad Overview

- 26% of generation in Eastern Interconnection
- 28% of load in Eastern Interconnection
- 19% of transmission assets in Eastern Interconnection




KEY STATISTICS

PJM member companies	800+
millions of people served	60
peak load in megawatts	163,848
MWs of generating capacity	185,600
miles of transmission lines	59,750
GWh of annual energy generation	832,331
sources	1,365
square miles of territory	214,000
area served	13 states + DC
externally facing tie lines	142

**21% of U.S. GDP
produced in PJM**

As of 9/7/2012

The diagram consists of three interlocking gears of different colors: a green gear at the top left, a blue gear at the top right, and a larger orange gear at the bottom center. Each gear is connected to a callout box containing text and a numbered circle. The green gear is labeled '1', the blue gear is labeled '3', and the orange gear is labeled '2'.

Reliability

- Grid Operations
- Supply/Demand Balance
- Transmission monitoring

1

Regional Planning


- 15-Year Outlook


3

Market Operation

- Energy
- Capacity
- Ancillary Services

2






➔ Pricing method PJM uses to:


- ⇒ price energy purchases and sales in PJM Market
- ⇒ price transmission congestion costs to move energy within PJM RTO
- ⇒ price losses on the bulk power system

➔ Physical, flow-based pricing system:


- ⇒ how energy actually flows, NOT contract paths
- ⇒ Marginal cost of delivering one more MW to any location on the system








PJM Wholesale Cost YTD September 2012 (\$/MWh)



* Values are PJM averages and do not reflect potential locational cost differences.

PJM Wholesale Cost Full-Year 2011 (\$/MWh)





* Values are PJM averages and do not reflect potential locational cost differences.




Region Transmission Expansion Planning (RTEP) Process

- ❖ Ongoing and cyclical
- ❖ 15 year planning horizon
- ❖ Comprehensive and Holistic
- ❖ Collaborative
- ❖ NERC, RFC, PJM compliance
- ❖ FERC-approved





- ❖ Open
 - ❖ Transparent
 - ❖ Collaborative
- ❖ Topics...process, plans, FERC compliance, implementation issues...etc



Conceptual Time Line



RTEPP - analyses and results


RTEPP - development of transmission alternatives




TEAC – Meeting presentations; review and provide comment and recommendations on results and proposed alternatives...BUT... TEAC does not approve transmission plans.



Board of Managers – Reviews and approves system enhancements proposed by PJM. If approved, thereafter formally part of RTEP. (15-year reliability planning and endorsement for further market efficiency studies.)







NERC Transmission Planning Reliability Standards... Driver of Baseline Expansion

A No Contingencies	All Facilities in Service
B Event resulting in the loss of a single element.	Single Line Ground (SLG) or 3-Phase (3Ø) Fault, with Normal Clearing: 1. Generator 2. Transmission Circuit 3. Transformer Loss of an Element without a Fault
	Single Pole Block, Normal Clearing ^e : 4. Single Pole (dc) Line
C Event(s) resulting in the loss of two or more (multiple) elements.	SLG Fault, with Normal Clearing ^e : 1. Bus Section 2. Breaker (failure or internal Fault)
	SLG or 3Ø Fault, with Normal Clearing ^e , Manual System Adjustments, followed by another SLG or 3Ø Fault, with Normal Clearing ^e : 3. Category B (B1, B2, B3, or B4) contingency, manual system adjustments, followed by another Category B (B1, B2, B3, or B4) contingency
	Bipolar Block, with Normal Clearing ^e : 4. Bipolar (dc) Line Fault (non 3Ø), with Normal Clearing ^e : 5. Any two circuits of a multiple circuit towerline ^f
	SLG Fault, with Delayed Clearing ^e (stuck breaker or protection system failure): 6. Generator 7. Transformer 8. Transmission Circuit 9. Bus Section

D^d Extreme event resulting in two or more (multiple) elements removed or Cascading out of service.	3Ø Fault, with Delayed Clearing ^e (stuck breaker or protection system failure): 1. Generator 2. Transmission Circuit 3. Transformer 4. Bus Section
	3Ø Fault, with Normal Clearing ^e : 5. Breaker (failure or internal Fault) 6. Loss of towerline with three or more circuits 7. All transmission lines on a common right-of way 8. Loss of a substation (one voltage level plus transformers) 9. Loss of a switching station (one voltage level plus transformers) 10. Loss of all generating units at a station 11. Loss of a large Load or major Load center 12. Failure of a fully redundant Special Protection System (or remedial action scheme) to operate when required 13. Operation, partial operation, or misoperation of a fully redundant Special Protection System (or Remedial Action Scheme) in response to an event or abnormal system condition for which it was not intended to operate 14. Impact of severe power swings or oscillations from Disturbances in another Regional Reliability Organization.

Adopted by NERC Board of Trustees: February 8, 2005
Effective Date: April 1, 2005

Terminology...

- **Category A = “n” = Standard TPL-001**
- **Category B = “n-1” = Standard TPL-002**
- **Category C = “n-1-1”, “n-2” = Standard TPL-003**
- **Category D = “Extreme Events” = Standard TPL-004**

PJM Applied Analysis	Baseline	Feasibility Study	System Impact Study
Normal system / as-is, all facilities in service	Yes	Yes	Yes
System contingency analyses – single and multiple facility outages	Yes	Yes (limited set historically, moving forward all)	Yes
CETO/CETL load deliverability analyses	Yes	No	Generation = No Merch Xmiss = Yes
Generation deliverability	Yes	No	Generation = Yes Merch Xmiss = Yes
Short Circuit Analysis	Yes	Limited	Yes
Stability Analysis	Yes	No	Yes
“But for” cost allocation analysis	Yes	No	Yes


- **Generation or Merchant Transmission Interconnection and Generator Deactivation**
 - Market driven...based on market opportunity
 - Attachment Facilities are allocated to developer
 - Network Upgrades based on deliverability tests based on cost causality or impacts on the limiting facility
- **Baseline Upgrades at 500 kV or above**
 - Zonal peak-load ratio share of system peak
 - Merchant transmission allocated costs based on transmission withdrawal rights in their ISA
- **Baseline Upgrades below 500 kV**
 - \$5 million and less allocated to the zone in which the upgrade is located
 - Over \$5 million allocated based on zonal or merchant transmission DFAX (flow based) impact on the constrained facility...what is causing the need for the upgrade...proposed to be changed based on usage



- Must have a benefit-cost ratio of 1.25 to 1
- Costs
 - PV of total upgrade cost over 15 years based on estimated annual revenue requirement
- Energy and Capacity Market Benefits (15 year PV)
 - Changes in total production costs (70%)
 - Changes in total load energy and capacity payments (30%)
 - For 500 kV and above this would be all zones
 - For below 500 kV this would be only for zones that realize a decrease in payments

- **Baseline Upgrades at 500 kV or above**
 - Same reliability upgrades
 - Zonal peak-load ratio share of system peak
 - Merchant transmission allocated costs based on transmission withdrawal rights in their ISA
- **Modifications to Baseline Upgrades below 500 kV**
 - Same as reliability upgrades
- **Acceleration of Baseline Upgrades below 500 kV**
 - Compare allocation factors based on:
 1. DFAX impact on constraint relieved;
 2. LMP benefit over acceleration period, per LSE load payments;
 - If differential $\geq 10\%$, use relative LMP benefit; otherwise, use DFAX methodology
- **Economic Only Upgrades below 500 kV**
 - Pro rata share of reduction in load energy payments only to zones with reduced load payments


Value of Approved Upgrades Since 2000




Efficiency Gains through Expanding the RTO

PJM Market Expansion – A Case Study

AEP / Dayton / Commonwealth Edison
Integration into the PJM Market



Change in Transmission Interconnector flows




Key Study Conclusions:

- Bilateral Trading could only achieve 40% of the efficiency gains of LMP-based market
- Incremental benefit of LMP Market Integration = \$180 Million annually, Net Present Value over 20 yrs is \$1.5 Billion


Referenced with Permission: Source: Erin T. Mansur and Matthew W. White, "Market Organization and Efficiency in Electricity Markets," March 31, 2009, Figure 2, pg 50, discussion draft.

Dominion Integration Benefit: Increased Transfer Capability

Prior to Integration






After Integration




Recent Market and Policy Drivers Affecting Transmission Expansion


Forecast Comparison for RTO_ATSI_DUKE






Encouraging Demand Resources







National Average Delivered Prices, Spot Prices, and Energy Shares of Coal and Natural Gas in PJM




Capacity Factors of Natural Gas Combined Cycle and Combustion Turbine Generation







RPM Base Residual Auction Resource Clearing Prices (By Zone)



PJM Installed Capacity
Cleared in RPM







8/24/2012
 PJM BOM removes PATH and MAPP from RTEP.





Looking Ahead toward Future Expansion


Queue Fuel Mix Through Close of X Queue



Generator Interconnection Requests: Eastern Mid-Atlantic PJM and West/Central Pennsylvania








RPS Policies

www.dsireusa.org / December 2010



PJM's 2009 CO₂ whitepaper showed 15 GW of wind reduced LMP by \$5.00-\$5.50/MWh on average

2026		
Target Installed Nameplate based on State Targets	Solar	11,000
	Wind	41,000
	Total	52,000
Forecast Restricted Demand** (2011 PJM Load Forecast)		172,904
Installed Reserve Margin		20%
Installed Capacity Needed		207,485
Installed Capacity Credit***	Solar	4,180
	Wind	6,150
	Total	10,330
Current Installed Capacity		185,544
Additional Non-Renewable Capacity Needed		11,611

- * assuming 30% capacity factor for wind and 12% for solar
- ** assuming 10,000MW of DR
- *** assuming capacity values at peak are 15% for wind and 38% for solar

- Large volume of needed renewables does require transmission to be deliverable
 - Case specific and costs are assigned to new resource
 - Right now “public policy” projects would only be undertaken if they passed benefit-cost test for economic reasons or reliability criteria for reliability-based projects
- Questions about cost allocation
 - “State agreement approach” whereby parties who want the project and agree to it pay for it?

- Transmission may be the lowest cost contributor to wholesale costs but it is the enabling factor for vibrant, competitive wholesale markets
- Currently the biggest area for activity is reliability based projects on a more localized level
- Public policy issues under Order No. 1000 and associated cost allocation questions will remain front and center
 - Accounting for the market trends in planning process for reliability and economic based projects
 - State agreement approach vs. widespread allocation?
 - Flow-based vs. widespread allocation