LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SPT2005	Question Number	26
Question date	17th Sept 2013	Answer date	19th September 2013
Submission section question relates to	2: Project Description		
Topic	Business Model		
Question	Please explain how you have valued DSM as £2/kW.		
Notes on question			
Answer	This figure came from the lower range of cost savings associated with DSM in the Transform model which is based on the experience of all GB DNOs. The lower value has been chosen as we assume a high volume of low value events occurring in this project rather than vice versa. This is a project assumption which will be validated as part of the ongoing trials.		
Attachments			
Verbal Clarifications (Consultants)			