

LCN Fund Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	WPDT205	Question Number	7
Question date	29th August	Answer date	2nd September
Submission section question relates to	2: Project Description Early Bilateral		
Topic	Commercial		
Question	The specific DNO network constraint affects the Wadebridge area. Does the same constraint also affect other towns or localities?		
Notes on question			
Answer	<p>There are several areas that are triggering significant and costly reinforcement which include most of Cornwall, North Devon and Skegness for example. This reinforcement work is typically needs new, long 33kV lines to be built or 132kV re-conductoring work to be done. We have included the heat maps to indicate these areas across our licence area. WPD have had interactions with (at least) 16 similar community groups to similar to WREN across our patch who have been interested in innovative energy projects: 2 in S West, 3 in S Wales, 4 in W Midlands and 7 E Midlands. In addition RegenSW has recently sent us a letter confirming that there are 180 communities in just the South West region that aspire to the same principles of WREN.</p>		
Attachments	Letter from Regen SW, South West Heat Map, South Wales Heat Map, West Midlands Heat Map and East Midlands Heat Map.		

Verbal Clarifications (Consultants)	
---	--