

Network Innovation Competition Full Submission

Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	SPT EN 01	Question Number	25
Question date	03/09/2013	Answer date	05/09/2013
Submission section question relates to	Section 2.5		
Topic	Technical Description of project		
Question	Please clarify whether SCADA manufacturers will be involved in the hybrid state estimation aspect of the project and if so, at what stage.		
Notes on question			
Answer	<p>Yes, SCADA manufacturers with prior experience of using PMUs in State Estimation will be involved in the Hybrid State Estimation aspect. This work will be tendered in the first quarter of the project, with a view to commencing the project once the WAMS infrastructure is in place.</p> <p>The reference used for cost and scope in the preparation of the proposal was received from Alstom Grid, which is a global EMS supplier, and the supplier for Scottish Power's EMS. Other vendor solutions will be invited and assessed at the tendering stage.</p>		
Attachments			
Verbal Clarifications (Consultants)			