

LCN Fund Full Submission
Supplementary Answer Form

Tick if this answer is Confidential: ☐

Tick if this answer has been provided verbally: ☐

Project code:	ENWT205	Question Number	10
Question date	29 August 2013	Answer date	5 September 2013
Submission section question relates to	Section 2: Project Description – Early Bilateral		
Topic	Technical		
Question	What steps have been taken to ascertain any changes or increases in the disturbances experienced by customers?		
Notes on question			
Answer	<p>As well as being a controllable single phase circuit breaker the WEEZAP also has in-built sophisticated monitoring and fault location capabilities that allows the <i>eta</i> Project to monitor each phase on each LV way of the distribution substation.</p> <p>In addition to the data collected via the WEEZAP's monitoring capabilities in the Trial we will:</p> <ul style="list-style-type: none">• undertake a survey to understand whether customer perceive a change in their electricity supply; and• make communications channels available for customers to ask questions on the <i>eta</i> Project, the Trials and report their experiences.		
Attachments			
Verbal Clarifications (Consultants)			