

Received by email from East Riding Council

Here in the East Riding I believe we are now in the position where connections can only be made under 200KW for renewables onto the Low Voltage DNO network.

I'm advised that connections onto High voltage networks are now not possible in many areas of the East Riding of Yorkshire as the network is essentially full without major DNO infrastructure capacity increases.

This clearly is putting financial pressure on connectees as we are potentially having to fund up the increase in network capacity for the DNO with suggested costs from the DNO of £2M+.

If these pressures remain it is likely to stifle development of renewable energy sources and ultimately compromise our ability to meet our carbon reduction targets set out in the Kyoto Agreement.

Thanks for a window to comment.

Philip

Philip Matthews | Assistant Principal Engineer | Electrical