



Making a positive difference  
for energy consumers

## Capacity Market Rules Change

Reference number (to be  
completed by Ofgem):  
**P024**

<b>Name of Organisation(s) / individual(s):</b> E.ON	<b>Date Submitted:</b> 23rd January 2015
<b>Type of Change:</b> <input checked="" type="checkbox"/> Amendment <input type="checkbox"/> Addition <input type="checkbox"/> Revoke <input type="checkbox"/> Substitution	<b>If applicable, whether you are aware of an alternative proposal already submitted which this proposal relates to:</b>
<b>What the proposal relates to and if applicable, what current provision of Rules the proposal relates to (please state provision number):</b>  Definition of Demand Reduction Instruction referenced by the definition of Involuntary Load Reduction (ILR) in Rule 8.5.3 needs to be extended.	
<b>Description of the issue that the change proposal seeks to address:</b>  Rule 8.5.3 includes a number of definitions. The ILR definition refers to Demand Reduction Instructions which are defined in Rule 1.2 with reference to OC6.5 of the Grid Code. This misses a number of other forms of load reduction. We believe it should reference demand shed directly by the System Operator and OC6.6 of the Grid Code (automatic low frequency disconnection).	
<b>If applicable, please state the proposed revised drafting (please highlight the change):</b>  In Rule 1.2 extend the definition of Demand Reduction Instruction to include OC6.6 of the Grid code and demand shed directly by the SO.	
<b>Analysis and evidence on the impact on industry and/or consumers including any risks to note when making the revision - including, any potential implications for industry codes:</b>	
<b>Details of Proposer (please include name, telephone number, email and organisation):</b>  Steve Davies, E.ON UK, <a href="mailto:Stephen.davies@eon-uk.com">Stephen.davies@eon-uk.com</a> , 02476 183627	