

Making a positive difference Canacity Market Rules

for energy consumers Capacity Main	Ket Kules	
Change		
		Reference number(to be completed by Ofgem): P038
Name of Organisation(s) / individual(s): National Grid Electricity Transmission Ltd	Date Submitted: 23/01/2015	
Type of Change:	If applicable, whether you are aware of an	
⊠ Amendment	alternative proposal already submitted which this proposal relates to:	
☐ Addition	No	
□ Revoke		
☐ Substitution		
What the proposal relates to and if applicable, what current provision of Rules the proposal relates to (please state provision number):		
Rule 8.3.6 states that a new build CMU must present a certificate for the ITE confirming that is it satisfied the plant has met the necessary criteria. This certificate must be provided prior to the start of the delivery year		
Description of the issue that the change proposal seeks to address:		
Providing such a report prior to the start of the delivery could be impossible if the unit is commissioned in the September as it could take some months for the finances to be signed off and verified. Similarly if the substantial completion milestone is delayed it is impossible to meet that requirement.		
If applicable, please state the proposed revised drafting (please highlight the change):		
Review the timings for the reports		
Analysis and evidence on the impact on industry and/or consumers including any risks to note when making the revision - including, any potential implications for industry codes:		
The timings should be reviewed to allow all CMUs sufficient time to gather the information. We propose subject to further review that the report/certificate is provided [6] months after the commissioning and reconciliations take place, and include a process for recovering any excessive capacity payments if required.		
Details of Proposer (please include name, telephone number, email and organisation): James Greenhalgh,		
Capacity Mechanism Manager,		
National Grid Electricity Transmission, james.greenhalgh@nationalgrid.com, 01926 656169		