

Q38 Outputs

Please propose relevant timebound outputs or other end products against which the Roll-out will be assessed. This is a requirement of 6E.12(f) eg, X MW additional network capacity by Y date.

[A]:

Kilmarnock-Coylton (XY Route) Reconductoring, increased capacity 1600MVA per circuit by 31-March-2018

Coylton-Mark Hill (YY Route) Reconductoring, increased capacity at 1000MVA single circuit by 31-March-2018