

# Proposal for a Capacity Market Rules Change



Making a positive difference  
for energy consumers

Reference number (to be completed by Ofgem):  
CP113

Name of Organisation(s) / individual(s):  
E.ON / Steve Davies

Date Submitted:  
15th January 2016

Type of Change:

- Amendment
- Addition
- Revoke
- Substitution

If applicable, whether you are aware of an alternative proposal already submitted which this proposal relates to: **No**

What the proposal relates to and if applicable, what current provision of Rules the proposal relates to (please state provision number):

**Metering Test Schedule 6 – Meter Calibration Test**

Description of the issue that the change proposal seeks to address:

Part (1) of Schedule 6 requires meter calibration (as an option) and specifies in the table the calibration data required. Much of this data refers to 'Reactive Meter'. However, 'Meter' is defined in Rule 1.2 specifically as "a device for measuring Active Energy and/or Active Power". Thus, the reactive meter tests are not warranted as they lie outside the scope of metering as defined.

If applicable, please state the proposed revised drafting (please highlight the change):

**Remove the last three columns in the Table in Schedule 6**

Analysis and evidence on the impact on industry and/or consumers including any risks to note when making the revision - including, any potential implications for industry codes:

No negative impact. This amendment will make the rules clearer and avoid unnecessary work on the part of Applicant and others

Details of Proposer (please include name, telephone number, email and organisation):

Steve Davies  
02476 183627  
[Stephen.davies@eon-uk.com](mailto:Stephen.davies@eon-uk.com)  
E.ON