

*Electricity Network Innovation Competition Full Submission*  
**Supplementary Answer Form**

**Project: REVISE**

Tick if this answer has been provided verbally: ☐

Project code	WPD/EN/NIC/12	Question Number	13
Question date	21 August 2018	Answer date	23 August 2018
Submission section question relates to	Section 2		
Topic			
Question	P5 – the problem – substitution by fossil fuel power – does this relate to national generation, or to temporary mobile generation deployed by WPD?		
Notes on question	None		
Answer	Within the Problem we are referring to national generation, which would supply GB load when DG is curtailed or disconnected. In our business case calculations, we have determined that the energy curtailed during outages of DG would be supplied by this national generation, which is a mix of both renewable and non-renewable sources.		
Attachments	None		