

Gas Network Innovation Competition Full Submission
Supplementary Answer Form

Project: Commercial BioSNG Demonstration Plant

Tick if this answer has been provided verbally: ☐

Project code	NGGDGN02/1	Question Number	11
Question date	25/8/15	Answer date	27/8/15
Submission section question relates to	General		
Topic			
Question	What is the ongoing cost liability for NGG for operating the connection? Will there be any future revenue streams (charging) for NGG?		
Notes on question			
Answer	<p>The connection will be to the Wales & West Utilities network at Swindon. It is not anticipated that there will be any significant ongoing cost liability for WWU for operating the connection as WWU will not own the grid connection equipment (e.g. gas quality measurement, CV measurement, metering, etc) but will be responsible for the Remotely Operated Valve and telemetry only.</p> <p>There will be no net effect on WWU transportation revenues from this connection. WWU will charge a cost reflective charge for the operation of its assets at the entry point (essentially the Remotely Operable Valve and telemetry for gas quality readings). This revenue will form part of its allowed transportation revenue, and as this allowed revenue is price controlled, other charges will be adjusted to ensure that WWU only recovers its allowed revenue from all customers connected to its network.</p>		

Attachments	
-------------	--