Question		Proforma						Follow up to	Confidenti
No.	From	section	Criteria	Question	Date question asked	Date response required	Date received	Question #	al (y/n)
				This project aims "to provide additional services and help the System Operator to reduce voltage fluctuations at the					
				duration voltage dips". WPD states separately that it worked closely with National Grid to develop future plans etc.					
				There were several references to the provision of reactive power sources to the System Operator in the project					
			g) Robust methodology/ready to implement	proposal and yet there was no letter of support from National Grid. This may call into question the robustness of the					
				project methodology. For example, on page 26, the proposal states: "There is a commercial risk associated with whether the device can be used to provide reactive power to the System Operator (National Grid), for what duration					
				and availability, and for what level of income.". Is National Grid a project partner and, if not, why has it not					
1	CO	n/a		committed to the project?	22 August 2017	24 August 2017	24 August 2017		
2	со	n/a	g) Robust methodology/ready to implement	Has the safety implications of using these devices in the system been considered in full and have bodies such as the HSE been consulted?	22 August 2017	24 August 2017	24 August 2017		
				Your submission shows the financial benefits of the proposed trial method versus conventional reinforcement.					
				Please explain why conventional reinforcement is the most efficient method in use today. Have you considered other methods to address the problem, eq. ANM or DSP. Within the Power report (which accompanied the Inpovation					
			a) Enviro+consumer bens	Review) you contributed data to indicates 37% of the methods trialled under the LCN Fund are ready for use in					
				business as usual and a further 41% are ready for use in the right circumstances. This would imply that there are					
3	NC	n/a		more efficient methods available to licensees than traditional reinforcement.	24 August 2017	29 August 2017	29 August 2017		
4	NC	n/a	d) Is innovative	With specific reference to the TRL definition in the governance document please justify the stated TRLs within the submission.	31 August 2017	05 September 2017	05 September 2017		у
			a) Envirotconsumer bens	We note your response to question 3. Please provide more information on why you have not considered 'quad-					
5	EP	n/a		boosters' to be the counterfactual technology?	05 September 2017	07 September 2017	07 September 2017		
6	FP	n/a	d) is innovative	For the six overseas deployments outlined within the submission, where known please outline why this option has been selected over a quad-hooster	05 Sentember 2017	07 Sentember 2017	07 Sentember 2017		
7	EP	n/a	d) Is innovative	Please provide a comparison table showing the capabilities for the device compared to a quad-booster.	05 September 2017	07 September 2017	07 September 2017		
8	EP	n/a	g) Robust methodology/ready to implement	How do you propose to control this device if it is established on the network?	05 September 2017	07 September 2017	07 September 2017		
9	EP	n/a	a) Enviro+consumer bens	Please clarify why the NPV for GB is positive but the use case/ licensee scale benefits are negative?	05 September 2017	07 September 2017	07 September 2017		
10	EP	3	a) Enviro+consumer bens	Please outline how the benefits in Table 3.3 link to those in the Benefits Tables in the Appendix?	05 September 2017	07 September 2017	07 September 2017		
11	EP	n/a	Multiple	How much appetite have other DNOs shown in using this technology if it is proved to be effective?	05 September 2017	07 September 2017	07 September 2017		
12	50		A. 111-1	We note the proposed device is rather large and likely to meet opposition from nearby residents. Please provide	05.6	07.0	07.000		
12	EP	n/a	Multiple	more information on the customer engagement steps you will take to overcome any issues caused by this.	05 September 2017	07 September 2017	07 September 2017		V
15	LF	11/4		We note your response to question three. Please provide a calculation of the benefits of LIPEC technology where	05 September 2017	07 September 2017	07 September 2017		У
14	EP	n/a	a) Enviro+consumer bens	other individual devices could be used instead, eg 'quad-boosters'.	05 September 2017	07 September 2017	07 September 2017		
15	NC	Appendices	a) Enviro+consumer bens	Please explain why the capacity 'benefits' are negative?	05 September 2017	07 September 2017	07 September 2017		
				Please explain whether there are carbon/environmental benefits associated with building a UPFC compared to					
				current business as usual approaches or indeed whether current methods have lower levels of embedded carbon					
16	NC	Appendices	a) Enviro+consumer bens	associated with their manufacture and construction.	05 September 2017	07 September 2017	07 September 2017		
17	NC	Appendices	b) Value for money	How likely is it that enough UPPCS will be rolled out to deliver a financial benefit to customers, UPPCS only appear to deliver a benefit based on a GB rollout.	05 September 2017	07 September 2017	07 September 2017		
18	со	n/a	b) Value for money	Can you please provide the day rates used and the estimated hours for this project for the WPD team and all the Partners / Contractors participating in the project?	05 September 2017	07 September 2017	07 September 2017		
				Please confirm how much money the project will have spent by the point where it would have to be stopped if a					
19	EP	n/a	b) Value for money	provider of the technology cannot be found? Place confirm whether the Carbon Figures calefy relate to CO2. If not, places list the other Greenbourg Carbon	12 September 2017	14 September 2017	14 September 2017		
20	EP	n/a	a) Enviro+consumer bens	included within the figure.	12 September 2017	14 September 2017	14 September 2017		
21	EP	n/a	a) Enviro+consumer bens	Please could you also confirm how much Carbon is embedded within the technological solution?	12 September 2017	14 September 2017	14 September 2017		
				What risks are there to the delivery of the project/ the GB roll-out by issues relating to planning permission? How are					
22	EP	n/a	g) Robust methodology/ready to implement	you intending to mitigate these/ is there any budget assigned?	12 September 2017	14 September 2017	14 September 2017		
23	EP	n/a	b) Value for money	Please could you confirm whether your agreement with Mott Macdonald/ the provider of the UPFC technology will include any royalty mechanism to ensure GB Consumers receive good value for the trial?	12 September 2017	14 September 2017	14 September 2017		
24	FP	n/a	b) Value for money	Please outline how you have ensured the contribution from Mott Macdonald represents good value for money to GB	12 Sentember 2017	14 September 2017	14 September 2017		
24	CP	ii/d		details on the content of this report and whether it identifies any required interactions with the Environment	12 Jepteniber 2017	14 September 2017	1+ September 2017		
25	EP	n/a	a) Enviro+consumer bens	Agency?	12 September 2017	14 September 2017	14 September 2017		
26	EP	n/a	b) Value for money	Please provide a comparison of the benefits offered by the UPFC compared to other similar alternative technologies	12 September 2017	14 September 2017	14 September 2017		
27	EP	n/a	c) Generates new knowledge	solution on their network if it is proven to be successful	12 September 2017	14 September 2017	14 September 2017		
28	NC	9	Multiple	percentage of funding associated with deliverable one is appropriate.	14 September 2017	19 September 2017	19 September 2017		
20	NC	_	Multiple	Please explain what is innovative and what new learning is associated with project deliverable two. Please provide a instification that the proposed percentage of funding associated with this deliverable is appropriate.	14 Sentember 2017	10 September 2017	10 September 2017		
29	NC	3	wuttple	positivation that the proposed percentage of funding associated with this deliverable is appropriate.	TA Sehreniner 2017	13 September 2017	19 September 2017		

				The proposed funding allocated to Project Deliverable 3 appears high given these are business as usual processes that					
				are undertaken when commissioning new equipment and are not directly linked to project learning. Please provide a					
30	NC	9	Multiple	justification that the proposed percentage of funding associated with this deliverable is appropriate.	14 September 2017	19 September 2017	19 September 2017		
				Project deliverables 4-10 appear to be associated with the outputs of the project and the learning that will be shared.					
				Please provide a justification that the proposed percentage of funding associated with these deliverables is					
31	NC	9	Multiple	appropriate.	14 September 2017	19 September 2017	19 September 2017		
				Please explain in more detail (with reasons) how you think the royalty arrangements proposed comply with Chapter					
32	NC	N/A	b) Value for money	10 of the Governance Document.	21 September 2017	26 September 2017	26 September 2017	23	
				Please comment on the carbon benefits of capacity released with current business-as-usual approaches and their					
				comparison with those of the proposed method (440,000 tCO2e by 2040).					
33	EP	Appendices	a) Enviro+consumer bens	Please clarify which scenario from FES was used to derive the estimate of carbon benefits.	21 September 2017	26 September 2017	26 September 2017	16	
				In various responses to the Q&A the use of quadrature boosters (QBs) as the counterfactual have been explored,					
				either alone or in combination with other devices depending on the constraint being relieved. Together with the					
				clarification that QBs are available at 132kV and based on relieving (real) constraints currently considered present on					
				the 132kV and 66kV systems (please justify whether the "fast" response of UPFCs are required), do your original CBA					
34	EP	n/a	Mulitple	and NPV calculations still hold? If not can you please revise your estimates.	05 October 2017	10 October 2017	10 October 2017		
				During the 2nd Bi-lateral Meeting you presented a table (page 6 of your notes) showing the networks in the WPD					
				licence areas where UPFCs may be the best solution to relieve network constraints. Can you please clarify how many					
				UPFCs per network (GSP) are required. For example, in the Cardiff East – Aberthaw network only one may be needed					
35	EP	n/a	Mulitple	but the table suggests two.	05 October 2017	10 October 2017	10 October 2017		

Electricity Network Innovation Competition Full Submission

# Supplementary Answer Form

### Project: \_\_\_\_WPD HARP\_\_\_\_\_

Tick if this answer has been provided verbally:  $\Box$ 

-					
Project code	WPD/EN/NIC/04	Question Number	1		
Question date	22/08/17	Answer date	24/08/17		
Submission section question relates to	n/a				
Торіс	g) Robust methodology/ready to i	mplement			
Question	This project aims "to provide addit Operator to reduce voltage fluctual transmission network supplies the term fluctuations and longer durat separately that it worked closely w plans etc. There were several refer power sources to the System Oper there was no letter of support from question the robustness of the pro- page 26, the proposal states: "The with whether the device can be us System Operator (National Grid), f and for what level of income.". Is if not, why has it not committed to	his project aims "to provide additional services and help the System perator to reduce voltage fluctuations at the point where the ansmission network supplies the distribution network, both short- rm fluctuations and longer duration voltage dips". WPD states parately that it worked closely with National Grid to develop future ans etc. There were several references to the provision of reactive ower sources to the System Operator in the project proposal and yet ere was no letter of support from National Grid. This may call into uestion the robustness of the project methodology. For example, on age 26, the proposal states: "There is a commercial risk associated ith whether the device can be used to provide reactive power to the ystem Operator (National Grid), for what duration and availability, and for what level of income.". Is National Grid a project partner and, not, why has it not committed to the project?			
Notes on question					
Answer	The Project Team has not requested N Project Partner or formal Project Supp	ational Grid to become orter at this time.	either a formal		
	We held discussions with Graham Stein within National Grid on 30 May 2017. T around provision of reactive power sup network, prior to receiving responses of Request for Information (RFI). We rece 21 June 2017. We have also subseque bid submission to Graham Stein for an	n of the GB System Ope This was an in-principle oport from devices on the from UPFC manufactures eived the manufacturer ntly provided a redacted vareness. The comment	rator function discussion e distribution rs to our responses on d copy of the full which we made		

future plans" relates specifically to the work which WPD have carried out to forecast reinforcement needs on their 132kV networks between now and 2030, rather than the discussion around reactive power provision.

The reason that we chose not to ask National Grid to formally support the project was two-fold.

Firstly, during the development of our bid, National Grid had launched its consultation "System Needs and Product Strategy", and which closed on 18th July. The scope of this consultation is all of the ancillary services procured by the System Operator including reactive power; National Grid are currently considering the responses from that consultation. Within the consultation document (page 21) National Grid state that "We must create a market that values reactive power in a transparent manner and aim to do this by the end of 2018/19. This design will begin following consultation and will use the results of Power Potential and Project Phoenix." This position was also confirmed by Graham Stein during our discussions. This gave us confidence that there is likely to be a means for distribution network assets to offer reactive power as a service alongside other competing providers, but that it was unlikely that National Grid could be seen to endorse further projects or initiatives during this consultation period. The System Operability Framework (SOF) published in 2016 by National Grid also states (page 102) that "Of the growing requirement for voltage control resources, a greater proportion must be dynamic in order to follow the daily reactive load profile and ensure voltage containment and recovery after a disturbance." This is to the advantage of UPFCs which can provide both static and dynamic reactive power.

Secondly, we would expect any future arrangements to be on a commercial arms-length basis and not necessarily as a project "sponsor" or Project Partner as defined by the Network Innovation Competition Governance Document. No contract is in place with National Grid regarding this project at this time.

#### The scope of the HARP project

Our intention set out in Section 7 (page 44) of the Full Submission is not to carry out any activity within the HARP project on the commercial arrangements for providing reactive power, but to rely on the existing activity between National Grid and the projects Power Potential (also known as "Transmission and Distribution Interface 2.0") and Project Phoenix as stated in their consultation document and which are compatible with the timescales of HARP set out in our project plan.

The scope of the project will include:

1. Confirmation of R017 in the project risk register in Appendix 10.5 (page 69 of the PDF Full Submission) whether there is indeed any conflict between a typical operating regime for the UPFC (such as that shown on page 12 of our submission) to serve both longer duration voltage dips and the needs of the distribution network. This risk was also referred to on page 26 of our submission. This will be confirmed by discussion with National Grid with respect to their service requirements; confirmation of the distribution network needs through

	<ul> <li>trials; confirmation that a compatible operating regime exists; and confirmation through trials that the UPFC can carry out the operating regime. This will be reported as part of the project deliverables 4 through 7 listed in Section 9 (page 47).</li> <li>2. Confirmation of the extent to which the UPFC, at the size installed, can contribute to attenuating a short-term voltage fluctuation. This will be reported as Project Deliverable 9 listed in Section 9 (page 48).</li> </ul>				
Attachments	-				
Project code	WPD/EN/NIC/04	Question Number	2		
Question date	22/08/2017	Answer date	24/08/2017		
Submission section question relates to	N/A				
Торіс	g) Robust methodology/ready to implement				
Question	Has the safety implications of using these devices in the system been considered in full and have bodies such as the HSE been consulted?				
Notes on question					
Answer	The Project Team has not consulted with HSE or similar bodies during development of these proposals. This was not considered necessary since the UPFC can be broken down into a series of major sub-assemblies, each of which has previously been deployed in the UK and has been demonstrated to be compliant with UK Health & Safety legislation and good industry practice.				
	The main requirements to achieve safety of electrical systems within the Electricity Supply Industry are set out in the following legislation:				
	<ul> <li>Electricity at Work Regulations 1989</li> <li>Electricity Safety, Quality &amp; Continuity Regulations (ESQCR) 2002 (as amended in 2006 &amp; 2009)</li> </ul>				
	Compliance with the WPD Safety Rules and associated procedures will also be essential.				
	We are familiar with the requirements of these Regulations/Safety Rules and are confident that, in all respects, a UPFC can be designed to be fully compliant with them. Compliance with this legislation (and all other relevant				

	UK legislation) will be a condition of Contract and we will be ensuring conformity through a comprehensive technical review of the manufacturer's design proposals by experienced professional staff. We have already included several normative standards and legislation within our Request for Information (RFI) against which manufacturers have provided indicative prices.
	It is proposed that the Principal Designer role is held by Mott MacDonald Ltd, who have extensive experience of managing power sector construction projects in the UK. We will follow established procedures for identifying risks, including comprehensive Hazard Reviews with input from both the Contractor and WPD operational staff. As will all WPD innovation technology projects, detailed design, type testing and routine testing will take place - witnessed by WPD's or Mott MacDonald's engineers.
	The full life cycle of the project will be managed in accordance with the Construction (Design & Management) Regulations (CDM) 2015. Mott MacDonald as Principal Designer will ensure that detailed maintenance recommendations are developed and documented in coordination with the equipment manufacturer, as well as other information that could be pertinent to the safe operation of the UPFC.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	3		
Question date	24/08/2017	Answer date	29/08/2017		
Submission section question relates to	N/A				
Торіс	a) Enviro+consumer bens				
Question	Your submission shows the financia method versus conventional reinfor conventional reinforcement is the r Have you considered other method or DSR. Within the Poyry report (w Review) you contributed data to in trialled under the LCN Fund are rea a further 41% are ready for use in would imply that there are more ef licensees than traditional reinforce	Your submission shows the financial benefits of the proposed trial method versus conventional reinforcement. Please explain why conventional reinforcement is the most efficient method in use today. Have you considered other methods to address the problem, eg ANM or DSR. Within the Poyry report (which accompanied the Innovation Review) you contributed data to indicates 37% of the methods trialled under the LCN Fund are ready for use in business as usual and a further 41% are ready for use in the right circumstances. This would imply that there are more efficient methods available to licensees than traditional reinforcement.			
Notes on question					
Answer	We agree that ANM and DSR are indeed under the LCN Fund which are ready for other alternative arrangements for com- already being considered by Western Po- to traditional network reinforcement. We published its current plan for ANM depli- currently lists 20 locations at which ANM Our bid however reflects that ANM and circumstances". WPD's series of reports	d examples of the meth r use in business as usu necting distributed gene ower Distribution first a /estern Power Distributi oyment on its website a M is being considered <sup>1</sup> . DSR are ready for use ` s ``Shaping subtransmiss	ods trialled ual. Alongside eration, ANM is s an alternative on has and which "in the right sion to		

<sup>&</sup>lt;sup>1</sup> <u>https://www.westernpower.co.uk/Connections/Generation/Alternative-Connections/ANM-Further-Info.aspx</u>

	<ul> <li>2030"<sup>2,3,4</sup> which carried out comprehensive analysis of the South West, South Wales and West Midlands licence areas concluded that a blend of ANM and conventional reinforcement is required.</li> <li>Both ANM and DSR require either generation or demand customers to be flexible with their network capacity and change their operational behaviour. This by nature relies on the customers wanting to participate in a DSR programme or accepting curtailment. There is a finite limit to the flexilibility</li> </ul>
	which customers can provide – either because there is a finite limit to the amount of industrial and commercial demand which can be shifted within a geographic region without disrupting a customer's business activities, or because distributed generators who join later may see an increasing and eventually uneconomic level of curtailment.
	The UPFC increases the flexibility of the distribution network itself and is therefore most comparable with conventional reinforcement. It is a complementary technology which can be rolled out alongside either ANM or DSR. Importantly, our analysis of applicability to Great Britain set out in Appendix 10.10, section 10.10.5, indicated that 23 sites had constraints which would eventually surpass the capabilities of ANM or DSR and would have to choose between conventional reinforcement or an alternative such as a UPFC in order to continue to accommodate generation and demand growth.
Attachments	

<sup>&</sup>lt;sup>2</sup> <u>https://www.westernpower.co.uk/docs/About-us/Our-business/Our-network/Strategic-network-investment/East-Midlands/Shaping-subtransmission-to-2030-East-Midlands-2017.aspx</u>

<sup>&</sup>lt;sup>3</sup> https://www.westernpower.co.uk/docs/About-us/Our-business/Our-network/Strategic-networkinvestment/Shaping-Subtransmission-to-2030-(South-Wales-2016).aspx

<sup>&</sup>lt;sup>4</sup> <u>https://www.westernpower.co.uk/docs/About-us/Our-business/Our-network/Strategic-network-investment/Shaping-Subtransmission-to-2030-South-West-2016-v1.aspx</u>

Project code	WPD/EN/NIC/04	Question Number	4
Question date	31/08/17	Answer date	05/09/17
Submission section question relates to	n/a		
Торіс	d) is innovative		
Question	With specific reference to the TRL of document please justify the stated	lefinition in the gover TRLs within the subn	rnance nission.
Notes on question			
Answer	*Marked as confidential*		
Attachments			
Project code	WPD/EN/NIC/04	Question Number	5
Question date	05/09/2017	Answer date	07/09/201 7

Submission section question relates to	N/A
Торіс	a) Enviro+consumer bens
Question	We note your response to question 3. Please provide more information on why you have not considered 'quad-boosters' to be the counterfactual technology?
Notes on question	
Answer	Our response to question 3 concentrated on the two specific technologies which were mentioned, Active Network Management (ANM) and Demand Side Response (DSR).
	We provided further detail in Appendix 10.9 on pages 77-79 of the bid how we chose the counterfactual, and referenced it in Section 3.1. Appendix 10.9 specifically discusses Thyristor-Switched Series Capacitors, quadrature boosters and STATCOMs as potential counterfactuals.
	In the case of the quadrature booster we presented the results of some comparative simulations between phase-shifting transformers and the UPFC. Three considerations were involved in our decision to use conventional reinforcement as the counterfactual for the DNO, and procuring reactive power services from alternative sources as the counterfactual for the GB System Operator:
	<ol> <li>the range of control required</li> <li>the dynamic response in the event of an outage</li> <li>the dynamic response in the event of voltage disturbance.</li> </ol>
	Further details can be found in Appendix 10.9.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	6		
Question date	05/09/17	Answer date	07/09/17		
Submission section question relates to	n/a				
Торіс	d) Is innovative				
Question	For the six overseas deployments outlined within the submission, where known please outline why this option has been selected over a quad-booster.				
Notes on question					
Answer	In all three cases which we could review UPFC is preferred to a quad booster (Qu controlling real power flow on the line a voltage support however the UPFC is ca control and reactive power compensation	w based on public inforr B) as the QB is only cap and is not capable of pro apable of controlling rea on.	nation, the bable of oviding Il power flow		
	One of the six examples of a UPFC bein American Electric Power Inez Station (H Unified Power Factor Controller (UPFC) that contingency analysis of the Inez per contingency outages could result in a d overload condition. It was identified th increased losses in the event of a single levels being reduced to unacceptable levels being reduced to unacceptable.	ig deployed was the app Kentucky). The 'CIGRE Task Force 14.27' docu ower station identified s epressed voltage and/o nat the requirement to s e outage would result in evels and a second conti	blication at the – TB 160 ment explains everal single r a thermal support n area voltage ingency was		
	Section 3.2.4 of the CIGRE document s constructing a high capacity 138 kV line 345 kV line would provide an economic to the area however such a line would a loading based on the high thermal capa be governed by the line impedance and well as the thermal capacity issue, the voltage performance during peak and o voltage support was also required in co capacity.	tates after extensive an e with thermal capabiliti al solution to adding the not be capable of sharin acity alone and power fl l other AC network para Inez area required impro off peak conditions there njuction with increased	halysis, that ies nearing a ermal capacity ng its line ow would still ameters. As rovements in efore dynamic thermal		
	Korea (Mokpo & Gwangju) – to overcor overloads for severe contingencies. (Re	ne problems of low volt f: CIGRE paper B4-306	ages and Control		

	<ul> <li>Strategies Study for KEPCO UPFC Operation Automation in Korean Sub- Transmission System, 2006)</li> <li>Korea (KangJin) – solution to under voltage and overload issues during system faults, UPFC was preferred over conventional reinforcement due to risk of delay or cancellation of reinforcement project due to environmental contraints or legal matters such as compensating land owners. (Ref: CIGRE paper B4-211 Commissioning and Testing of the KangJin UPFC in Korea, 2004)</li> </ul>				
Attachments					
Project code	WPD/EN/NIC/04	Question Number	7		
Question date	05/09/2017	Answer date	07/09/201 7		
Submission N/A section question relates to					
Торіс	d) Is innovative				
<b>Question</b> Notes on	Please provide a comparison table showing the capabilities for the device compared to a quad-booster.				
question					

Answer	We have summarised the submission. We have pro	capabilities of each device below against the varies of each device below against the varies ovided further commentary in the form of footnote	ous functions which are discussed in the HARP s:	
	Function	Capabilities with respect to this function		
		Quadrature booster	UPFC	
	Re-direct power away from constrained sections of a ring (Case Study 2 or Case Study 3)	Quadrature boosters have a coarser degree of control based upon discrete tap settings and a fixed phase relationship between the shunt and series windings <sup>5</sup> It is generally not possible to select the most effective phase relationship (which is not necessarily 90 degrees) between the shunt and series windings. The line compensation cannot, therefore, be optimised.	Fine degree of control capable through adjusting the output voltage of the 'Series' VSC bridge. As the coupling between the shunt and seies elements is through a DC link, the phase relationship between system voltage and the injected voltage can be adjusted in real time to optimise line compensation	
	Reduce "reverse" power being presented to Super-Grid Transformers on the transmission network (Case Study 3)	Same as line above	Same as line above	
	Re-direct power to avoid overloads in the event of a system fault or outage (Case Study 1)	Same as line above	Same as line above	
	Control both real and reactive power flows in the circuit in which the unit is connected	The QB cannot control real and reactive power flows independently. In general, a QB is used to control MVA transfers (i.e. real + reactive current combined).	The UPFC allows the phase relationship between the system voltage and the injected voltage to be adjusted over a wide range. This allows real power flows and reactive power flows to be independently controlled. The benefit of this is that a circuit can be operated with an optimised reactive transfer, minimising the thermal capacity of the circuit that is 'wasted' transferring reactive power. For example, a cable generates	

<sup>&</sup>lt;sup>5</sup> We quantified in Appendix 10.9, page 78, that this coarse control may amount to around 10-20MW less capacity able to connect at each 132kV/33V or 66kV/11kV substation around a ring than if a UPFC was used.

		reactive power along its length and its rating can be optimised if 50% of the reactive power generated is transferred into the network at each end of the circuit (i.e. no more than 50% flows in any part of the cable). A UPFC allows this transfer to be controlled whilst still permitting flexible control of real power flows. A further benefit of managing reactive power flows is that transmission losses can be minimised through limiting the total current flowing in the circuit (real + reactive).
Provide reactive power compensation to the upstream 66kV or 132kV busbar and the 275kV or 400kV busbar from which these are fed	Cannot directly provide reactive power compensation (any compensation achieved is a secondary effect and unctrolled).	Able to provide both inductive or capacity compensation from the shunt section.
Reduce voltage fluctuations by injecting a voltage which seeks to damp the fluctuation	A 'classic' quadrature booster relies on operation of a mechanical tapchanger to adjust the power flow in the circuit to which it is connected. Tapchangers are designed to operate step by step through their range, and each step will typically take 0.1 - 0.2s to complete. Thus a QB may require several minutes to achieve a significant change. <sup>6</sup> During this time the circuit or other assets would be exposed to the overload. As such, other faster-acting arrangements may be required such as inter-trip arrangements with generators.	A UPFC is able to alter its operating point rapidly (typically 20-40ms response time) to any point in its operating range. This allows the UPFC to respond to, and assist in managing, transient events on the network. This dynamic response allows the network to be operated closer to its thermal limits whilst still remaining stable during contingency events (typically system faults).

<sup>&</sup>lt;sup>6</sup> To improve the flexibility of the QB, the mechanical tapchanger can be replaced with a power electronic current controller (based on thyristor technology). Although these units are capable of providing fast-acting response, they have the disadvantage that harmonics generated by the thyristor controller are injected directly into the line. Harmonic control measures may thus be required at additional cost.

Question date         05/09/17         Answer date         07/09/17           Submission section question relates to         n/a                                                                                                              <	Project code	WPD/EN/NIC/04	Question Number	8
Submission section question relates to       n/a         Topic       g) Robust methodology/ready to implement         Question       How do you propose to control this device if it is established on the network?         Notes on question       In a similar manner to previous innovation projects led by Western Power Distribution such as Active Network Management (ANM) and System Voltage Optimisation (SVO) the UPFC will integrate with the PowerOn Fusion control system (WPD's standard network management systems) either directly or through an Inter-Control Room Communications Protocol (ICCP) link.         We propose to control this device in a 24 hour operating regime that will set the control objectives of the UPFC for each hour of the day. The control objectives for the UPFC will be established during the trials design period of the programme in conjuction with WPD engineers and National Grid to explore the benefits of income from UPFC services to National Grid	Question date	05/09/17	Answer date	07/09/17
Topicg) Robust methodology/ready to implementQuestionHow do you propose to control this device if it is established on the network?Notes on questionIn a similar manner to previous innovation projects led by Western Power Distribution such as Active Network Management (ANM) and System Voltage Optimisation (SVO) the UPFC will integrate with the PowerOn Fusion control system (WPD's standard network management systems) either directly or through an Inter-Control Room Communications Protocol (ICCP) link.We propose to control this device in a 24 hour operating regime that will set the control objectives of the UPFC for each hour of the day. The control objectives for the UPFC will be established during the trials design period of the programme in conjuction with WPD engineers and National Grid to explore the benefits of income from UPFC services to National Grid	Submission section question relates to	n/a		
Question       How do you propose to control this device if it is established on the network?         Notes on question       In a similar manner to previous innovation projects led by Western Power Distribution such as Active Network Management (ANM) and System Voltage Optimisation (SVO) the UPFC will integrate with the PowerOn Fusion control system (WPD's standard network management systems) either directly or through an Inter-Control Room Communications Protocol (ICCP) link.         We propose to control this device in a 24 hour operating regime that will set the control objectives of the UPFC for each hour of the day. The control objectives for the UPFC will be established during the trials design period of the programme in conjuction with WPD engineers and National Grid to explore the benefits of income from UPFC services to National Grid	Торіс	g) Robust methodology/ready to im	plement	
Notes on questionAnswerIn a similar manner to previous innovation projects led by Western Power Distribution such as Active Network Management (ANM) and System Voltage Optimisation (SVO) the UPFC will integrate with the PowerOn Fusion control system (WPD's standard network management systems) either directly or through an Inter-Control Room Communications Protocol (ICCP) link.We propose to control this device in a 24 hour operating regime that will set the control objectives of the UPFC for each hour of the day. The control objectives for the UPFC will be established during the trials design period of the programme in conjuction with WPD engineers and National Grid to explore the benefits of income from UPFC services to National Grid	Question	How do you propose to control this device if it is established on the network?		
AnswerIn a similar manner to previous innovation projects led by Western Power Distribution such as Active Network Management (ANM) and System Voltage Optimisation (SVO) the UPFC will integrate with the PowerOn Fusion control system (WPD's standard network management systems) either directly or through an Inter-Control Room Communications Protocol (ICCP) link.We propose to control this device in a 24 hour operating regime that will set the control objectives of the UPFC for each hour of the day. The control objectives for the UPFC will be established during the trials design period of the programme in conjuction with WPD engineers and National Grid to explore the benefits of income from UPFC services to National Grid	Notes on question			
For each control objective the UPFC will be required to to direct real power flow (Static Synchronous Series Compensator, SSSC action), provide reactive power compensation (STATCOM action) or provide a combination of real power control and reactive power compensation (SSSC and STATCOM action). Examples of control objectives are provided in Table 2.1 of the full submission document such as reduce energy lost to heat, protect against voltage disturbances, control power supplying demand, optimise power factor, control of active power flow from solar PV. Prior to each control objective being set, the UPFC will establish the existing network conditions using SCADA input and real time measurements and then, using its own software, iteratively perform future load flow assessments of the network offline to determine the required operating voltage and phase angle set points of the SSSC and STATCOM that will	Answer	In a similar manner to previous innovation projects led by Western Power Distribution such as Active Network Management (ANM) and System Voltage Optimisation (SVO) the UPFC will integrate with the PowerOn Fusion control system (WPD's standard network management systems) either directly or through an Inter-Control Room Communications Protocol (ICCP) link. We propose to control this device in a 24 hour operating regime that will set the control objectives of the UPFC for each hour of the day. The control objectives for the UPFC will be established during the trials design period of the programme in conjuction with WPD engineers and National Grid to explore the benefits of income from UPFC services to National Grid. For each control objective the UPFC will be required to to direct real power flow (Static Synchronous Series Compensator, SSSC action), provide reactive power compensation (STATCOM action) or provide a combination of real power control and reactive power compensation (SSSC and STATCOM action). Examples of control objectives are provided in Table 2.1 of the full submission document such as reduce energy lost to heat, protect against voltage disturbances, control power supplying demand, optimise power factor, control of active power flow from solar PV. Prior to each control objective being set, the UPFC will establish the existing network conditions using SCADA input and real time measurements and then, using its own software, iteratively perform future load flow assessments of the network offline to determine the required operating voltage and phase angle set points of the SSSC and STATCOM that will		
controllers within each device will then control the firing angles of the Insulated Gate Bipolar Transistors (IGBTs) to meet the control objectives.Attachments	Attachments	controllers within each device will then of Insulated Gate Bipolar Transistors (IGB	control the firing angles Ts) to meet the control	s of the objectives.

Project code	WPD/EN/NIC/04	Question Number	9
Question date	05/09/2017	Answer date	07/09/201 7
Submission section question relates to	n/a		
Торіс	a) Enviro+consumer bens		
Question	Please clarify why the NPV for GB is positive but the use case/ licensee scale benefits are negative?		
Notes on question			
Answer	The NPV was built up from an assumed roll-out of UPFCs to address individual instances of Case Study 1, Case Study 2, and Case Study 3.		
	Overall we believe that Case Study 1 and Case Study 3 will be more common than Case Study 2.		
	Within Western Power Distribution currently, there are examples of Case Study 1 (at [redacted]) but not examples of Case Study 3.		
	The most realistic case on which to base our post-trial or use-case scale benefits is Case Study 1 and a first installation in 2022.		
	The most realistic case on which to base our licencee scale solution is one installation of Case Study 1 in 2022 followed by a second installation of Case Study 3 in 2026. We added some notes to this effect in the column "Cross references" in the table on page 51 in Appendix 10.1.		ution is one llation of Case umn "Cross-
	Post-trial or use-case scale		
	The conservative assumptions we have used in Appendix 10.1 are that:		
	<ul> <li>the higher of the [redacted] manufacturer's prices that we have received at RFI is achieved, not the lowest price;</li> <li>the device does not earn reactive power income;</li> <li>installations subsequent to the project would be containerised and not require a building.</li> </ul>		
If we apply similar break-even analysis as we carried out in Table GB and licence-area scale benefits, we find that our existing post- is net positive over timescales to 2040 and 2040 if the lower of th manufacturer's prices that we have received at RFI is achieved, ar device earns income from delivering reactive power.		ble 3.5 to the ost-trial case f the two I, and the	

	Licensee scale
	We have found a formula error in the spreadsheet which we used to calculate the NPV benefits. We were calculating the NPV benefit at licensee scale correctly for 2030, and 2040, but incorrectly for 2050. The formula was calculating gross expenditure on the UPFC installation, not net benefit based on comparing it with gross expenditure on the counterfactual. The correct value is for the NPV at licencee scale in 2050 is £2.45m.
	As such, the licensee scale shows a positive NPV on timescales measured to 2030, 2040 and 2050. We will correct this in our re-submission.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	10
Question date	05/09/2017	Answer date	07/09/201 7
Submission section question relates to	3		
Торіс	a) Enviro+consumer bens		
Question	Please outline how the benefits in Table 3.3 link to those in the Benefits Tables in the Appendix?		
Notes on question			
Answer	<ul> <li>The summary in table 3.3 was presented in a simplified format, based only on the quantity of each Case Study which was included in the GB roll-out. It did not take into account the timing of the expenditure.</li> <li>The financial figures presented in the table in Appendix 10.1 is based on a fuller calculation which takes into account: <ul> <li>The year in which each subsequent installation is rolled out, using the profile presented in Appendix 10.10, Section 10.10.6.</li> <li>The time value of money, using the parameters set out in Appendix 10.10, Section 10.10.4</li> <li>Effects of capitalisation of expenditure, using the paramaters set out in Appendix 10.10, Section 10.10.4</li> <li>The effect of future cost reductions in the technology, based on the analysis presented in Appendix 10.10, Section 10.10.7</li> <li>Maintenance costs.</li> </ul> </li> </ul>		
	The conventional costs used in both Table 3.3 and in the fuller calculatio which informed Appendix 10.1 are explained in Appendix 10.10, section 10.10.4. The "UPFC unit cost" in Table 3.3 was derived in accordance with Figure and Table 3.4. In fuller detail, this included:		calculation , section th Figure 3.3
	Front-end Engineering Design (FEED) cost of 50% compared to the trial Site surveys and Detailed Design at th	activities at a reduced ne same cost as the trial	£0.10m £0.44m

	Land Purchase, cSite learance and preparation (incl. earthing orid) at the same cost as the trial	£1.53m
	UPFC cost	£10.40m
	Ancillary equipment at 32% of £2.10m required in the trial	£0.47m
	Telecomms and SCADA equipment at the same cost as the	£0.20m
	trial	
	£0.42m	
	Construction oversight and commissioning at 50% of the	£0.15m
	trials	
	[No requirement for programme management or learning and	-
	dissemination]	
	[No requirement for contingency]	-
Total		£13.71m
	Finally, the figures in red on the right in Table 3.3 provided total expenditure based on multiplying these costs through by the nui installations.	s for capital mber of
Attachments		

Project code	WPD/EN/NIC/04	Question Number	11
Question date	05/09/2017	Answer date	07/09/201 7
Submission section question relates to	N/A		
Торіс	Multiple		
Question	How much appetite have other DNOs shown in using this technology if it is proved to be effective?		
Notes on question			
Answer	Neither Mott MacDonald or Western Power Distribution has at this time formally asked the other DNOs about their appetite to replicate the solution if proven successful.		
	However, we would note that there is increasing interest in power electronic solutions as represented by the following recent projects:		
	<ul> <li>Western Power Distribution's Low Carbon Network Fund (LCNF) project "Network Equilibrium" (operating at 33kV)</li> <li>ScottishPower Energy Networks' project Network Innovation Competition (NIC) project ANGLE-DC (operating at 33kV)</li> <li>ScottishPower Energy Networks' Network Innovation Allowance (NIA) project "11kV power electronics providing reactive compensation for</li> </ul>		
	<ul> <li>voltage control"</li> <li>ScottishPower Energy Networks' Network Innovation Allowance (NIA) project "Technical Review of Non-conventional Statcom Applications" which is looking particularly at the 11kV network.</li> </ul>		
Attachments			

Project code	WPD/EN/NIC/04	Question Number	12
Question date	5 Sep 2017	Answer date	7 Sep 2017
Submission section question relates to	n/a		
Торіс	Multiple		
Question	We note the proposed device is rather large and likely to meet opposition from nearby residents. Please provide more information on the customer engagement steps you will take to overcome any issues caused by this.		
Notes on question			
Answer	One of the trial sites identified in Appendix 10.2 will be on land immediately adjacent to an existing sub-station. The other trial site would require establishing a new substation site. Both sites are bounded by farm land or other open areas and main roads. Neither of these sites has a boundary to residential or business areas. We had discounted trial sites where the location would have been directly next to or within residential areas (for example Stratford upon Avon, located opposite a residential area and with planned residential development around the existing sub-station).		
	Nevertheless we envisage the following	engagement with local	residents:
	<ol> <li>Compliance with all statutory planning communications requirements.</li> <li>General project information in existing WPD customer information publications.</li> <li>Follow Western Power Distribution's existing engagement strategy for similar new-build projects, where required providing specific project information, plans and impacts, and the measures to minimse any impacts during construction and operations.</li> <li>Ongoing project updates through in WPD customer publications and website, and progress updates in targeted publicity to local residents.</li> <li>The communications materials and planning application will address likely questions on disruption and routing of construction traffic, site construction noise, safety issues and supply interruptions as well as the project objectives and intended benefits. Specific publicity will be issued to warn of major equipment delivery.</li> </ol>		requirements. formation nt strategy for ecific project inimse any ications and ocal residents. dress likely construction ject objectives of major
Attachments			

Project code	WPD/EN/NIC/04	Question Number	13
Question date	05/09/2017	Answer date	07/09/201 7
Submission section question relates to	N/A		
Торіс	(e) Partners and external funding		
Question	Please outline the steps you have a suppliers of the device.	Iready taken to ident	ify likely
Notes on			
question			
Answer	*Marked as confidential*		
Attachments			

Project code	WPD/EN/NIC/04	Question Number	14
Question date	05/09/2017	Answer date	07/09/201 7
Submission section question relates to	N/A	i	
Торіс	a) Enviro+consumer bens		
Question	We note your response to question three. Please provide a calculation of the benefits of UPFC technology where other individual devices could be used instead, eg 'quad-boosters'		
Notes on question			
Answer	Our business case is focussed on rolling out UPFCs in locations which exhibit multiple challenges. We built our roll-out estimate to 23 locations by searching for signs of multiple different challenges which could not be solved by a single individual device (such as a quad-booster). The process by which we carried out this search is explained in the Appendix 10.10, section 10.10.5, pages 83-88.		
	Western Power Distribution would not typically roll out the UPFC to solve only one specific issue.		
	A number of our calculations presented in the bid can be used to draw conclusions as follows.		
	<ol> <li>Within our break-even analysis on page 20, table 3.3, we demonstrated that the added value of providing reactive power to GB System Operator National Grid is 6.2m in NPV terms, over the timescale from now to 2040. This is calculcated from the difference between a scenario in which the UPFC earns reactive power incom (£33.5m) and our base benefits case (£27.3m).</li> </ol>		we 'e power to the is, over the ne difference ower income
	A STATCOM, switched shunt reactor or capacitor bank are all examples of individual devices which could capture this $\pounds$ 6.2m of value but which would not be able to capture the underlying $\pounds$ 27.3m since they are not able to direct power to support the distribution network. By contrast, a quad-booster is able to capture most of the benefits associated with $\pounds$ 27.3m but is not able to capture this additional $\pounds$ 6.2m of benefits.		
	<ol> <li>In Appendix 10.9, we provided calculations on the capacity bener a UPFC against a phase shift transformer (PST) and shown that to UPFC is able to release more line capacity than the PST due to its control of the phase angle. We calculate this as increasing capacity which can join by 10-20MW, and which may be the difference</li> </ol>		acity benefits of own that the due to its finer ing capacity ference

	between an additional distributed generator being able to join the network or not being able to join the network. The unit cost of a UPFC is provided in Table 3.3 at £13.7m in 2018 prices, and prior to any discounts which may be achieved in future.
	The estimated cost of a 132 kV rated PST is provided in Appendix 10.9 at $\pounds$ 3.5-4.5m (2015 prices). These costs are not comparable as the UPFC technology provides the additional benefit of reactive power control. To achieve the same control objectives of the UPFC technology would require a STATCOM as well as a PST. The estimated cost of a STATCOM is provided in Appendix 10.9 at £3.5-5m.
	This equates to a total estimated cost of $\pounds$ 7-9.5m for a STATCOM and PST however this does not include any costs for the control and communication requirements of integrating both devices as a joint solution.
	Further work would be required to ensure that our data sources for the cost of PST and STATCOM are comparable "turn-key" costs including all associated switchgear, land purchase etc. and therefore comparable with our £13.7m turn-key cost of the UPFC.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	15
Question date	05/09/2017	Answer date	07/09/201 7
Submission section question relates to	Appendices		
Торіс	a) Enviro+consumer bens		
Question	Please explain why the capacity 'benefits' are negative?		
Notes on question			
Answer	We calculated the capacity benefits as net benefits:		
	Net capacity released = Capacity released by the UPFC (Method Case) –		
	Capacity released by conventional reinforcement (Base Case)		
	The capacity released by the UPFC was based on simulations carried out at [redacted] for Case Study 1, and simulations carried out at [redacted] for Case Study 2. The capacity released by conventional reinforcement was calculated from equipment ratings supplied by Western Power Distribution.		
	The capacity released in each Case Study for both the Method Case and Counterfactual is summarised in Table 3.3 in Section 3, on page 19. We wanted to be open and transparent that conventional reinforcement creat more capacity; but can only be purchased in large quantities, some of w may in fact be stranded capacity. Because we had no firm assumption that we could provide for the proport of capacity which might be unused or "stranded", we did not discount and the capacity created by conventional reinforcement.		Case and e 19. We ment creates ome of which
			the proportion scount any of
	As such, the net amount of capacity cre conventional reinforcement in each Cas negative when calculated in MVA terms	eated by the UPFC is low e Study, and the overal under these assumption	ver than I net benefit is ns.
Attachments			

Project code	WPD/EN/NIC/04	Question Number	16
Question date	5 Sep 2017	Answer date	7 Sep 2017
Submission section question relates to	Appendices		1
Торіс	a) Enviro+consumer bens		
Question	Please explain whether there are carbon/environmental benefits associated with building a UPFC compared to current business as usual approaches or indeed whether current methods have lower levels of embedded carbon associated with their manufacture and construction.		
Notes on question			
Answer	<ul> <li>We have not quantified the carbon or environmental benefits of a UPFC or other current methods (line reinforcement) within a distribution network.</li> <li>With Ofgem interest in quantified embedded carbon costs, it would be possible to create data sets for the UPFC installation as part of the project – suggested to be conducted in Work Package 3 (Studies) - assuming sufficient asset specification and material content information is provided by the manufacturer and DNO. Such data capture would demonstrate the viability and utility of the carbon capture tool for wider application for DNOs and Ofgem.</li> <li>Mott MacDonald has developed a mature carbon calculation tool that could perform such calculations, but does not possess any data sets for network assets within a distribution network.</li> <li>National Grid have developed data sets for transmission network assets, including for 132kV transmission lines. Whilst these data sets are proprietary to National Grid, indicative figures are that the carbon cost for a transformer installation is roughly equivalent to the carbon cost for 4km of overhead line.</li> <li>A UPFC installation requires 2 transformers, 3 to 4 circuit breakers and the UPFC equipment itself. However, the carbon cost for the civil works required for a containerised UPFC solution and the carbon cost required for a UPFC housed in a building would create a significant variance in any cost/benefit calculation.</li> </ul>		
	The other environmental benefits for a UPFC solution centre on the avoidance of the cumulative disruption associated with line reinforcement. The level of disruption is driven by actual line routing, and includes disturbance to		the avoidance . The level of ance to

	ecology along the lines, access to agricultural land over which lines are routed, noise and road restrictions for communities and business along the line route, the complexity of planning and community engagement along a route and the impact of network interruptions for consumers during reinforcement. These costs would need to be compared to the localised disturbance and disruption resulting from the UPFC site works.	
Attachments		

Question date05/09/2017Answer date07/09/20 7Submission section question relates toAppendices7Topicb) Value for moneyValue for moneyQuestionHow likely is it that enough UPFCs will be rolled out to deliver a financial benefit to customers, UPFCs only appear to deliver a benefit based on a GB rollout.	Project code	WPD/EN/NIC/04		Question Number	17
Submission section question relates to       Appendices         Topic       b) Value for money         Question       How likely is it that enough UPFCs will be rolled out to deliver a financial benefit to customers, UPFCs only appear to deliver a benefit based on a GB rollout.	Question date	05/09/2017		Answer date	07/09/201 7
Topicb) Value for moneyQuestionHow likely is it that enough UPFCs will be rolled out to deliver a financial benefit to customers, UPFCs only appear to deliver a benefit based on a GB rollout.	Submission section question relates to	Appendices			
Question How likely is it that enough UPFCs will be rolled out to deliver a financial benefit to customers, UPFCs only appear to deliver a benefit based on a GB rollout.	Торіс	b) Value for money			
	Question	How likely is it that enough UPFCs will be rolled out to deliver a financial benefit to customers, UPFCs only appear to deliver a benefit based on a GB rollout.			
question	Notes on question				
methodology set out in Appendix 10.10, section 10.10.5, on pages 83-86 of the submission. We established the roll-out profile using the methodology sout section 10.10.6, on pages 88-89 of the submission. Based on this we h the following roll-out assumptions in the early years:20221x installation to address Case study 1 20232023[No additional installs] 20242024[No additional installs] 202520251x installation to address Case study 3 202620262x installation to address Case study 2 2x installation to address Case study 2 2x installation to address Case study 3 202720271x installation to address Case study 3 202820281x installation to address Case study 3 202920291x installation to address Case study 320291x installation to address		methodology set out the submission. We er out section 10.10.6, or the following roll-out20221x integration 20232023[No ar 20242024[No ar 202520251x integration 1x integration 202820271x integration 202920291x integration 1x integration20291x integration 2029At the end of this per break-even analyses which carried out NPV demonstrated that th Network Innovation Comparison	e established the potential for 23 units to be rolled out from the ethodology set out in Appendix 10.10, section 10.10.5, on pages 83-86 of e submission. We established the roll-out profile using the methodology set it section 10.10.6, on pages 88-89 of the submission. Based on this we had e following roll-out assumptions in the early years: <u>2022</u> 1x installation to address Case study 1 <u>2023</u> [No additional installs] <u>2024</u> [No additional installs] <u>2025</u> 1x installation to address Case study 3 <u>2026</u> 2x installation to address Case study 4 <u>2x installation to address Case study 2</u> <u>2x installation to address Case study 3</u> <u>2027</u> 1x installation to address Case study 3 <u>2028</u> 1x installation to address Case study 3 <u>2029</u> 1x installation to address Case study 4 <u>2029</u> 1x installation to address Case study 4 <u>2029</u> 1x installation to address Case study 5 <u>2029</u> 1x installation to address Case study 4 <u>2029</u> 1x installation to address Case study 5 <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>2020</u> <u>20</u>		

	conventional sources and which strengthens the case for devices such as a UPFC which can provide these services.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	18
Question date	5 Sep 2017	Answer date	7 Sep 2017
Submission section question relates to	n/a		
Торіс	Value for Money		
Question	Can you please provide the day rates used and the estimated hours for this project for the WPD team and all the Partners / Contractors participating in the project?		
Notes on question			
Answer	<ul> <li>Please see attachment with requested information for WPD and Partner :</li> <li>WPD effort and day rates</li> <li>Mott MacDonald effort and day rates</li> </ul> For the other costs not included in the WPD, the Mott MacDonald or the manfuacturer's lump sum estimate provide in the Request for Information, we used unit costs drawn from industry standard or previous project data. Unfortunately we are not able to break the labour contribution within these unit costs down into day-rates: <ul> <li>Building costs were estimated using industry-standard data book "SPONS" against each manufacturer's site requirements. Site set-up and ongoing costs were estimated at 15% of net contract value. Professional fees were estimated at 10% of net contract value <ul> <li>Civil works site preparation, site survey requirements, and civils works themselves (earthing, foundations, fencing, etc) were priced using Mott MacDonald's project experience and then validated with WPD's construction team. Site set-up and ongoing costs were estimated at 20% of net contract value. Professional fees were estimated at 10% of net contract at 10% of net contract value</li> <li>Additional electrical equipment for connection to the distribution network, protection and control systems and telecoms with reference to actual data from previous UK substation projects for which Mott MacDonald has been the principal designer (primarily from National Grid South East Substation alliance where we were also the cost management lead). Site costs were already within the civil works estimate.</li></ul></li></ul>		

Attachments	Clarification Response to Question 18 - *marked as confidential*

Project code	WPD/EN/NIC/04	Question Number	19
Question date	12/09/17	Answer date	14/09/17
Submission section question relates to	N/A		
Торіс	b) value for money		
Question	Please confirm how much money th point where it would have to be sto technology cannot be found?	e project will have sp pped if a provider of	pent by the the
Notes on question			
Answer	Based on the submitted project plan (Appendix 10.4) and cost spreadsheet (Appendix A), the project spend at the point where the project would have to be stopped due to lack of technology provider would be in August 2018 (H1 Year 1) with a Total Cost of £1,222k. The Outstanding Funding Required at this stage is £1,059k. This equates to 7.2% of the Total Cost (or 7% of the NIC Funding Request).		
	The costs incurred include all work package (WP) costs in financial year 2017/18, WP1/2/3 costs in year 2018/19 and a 75% reduction applied to WP5 (Procurement) costs in year 2018/19 as it is expected that Mott MacDonald and WPD will spend some time and effort attempting to overcome any concerns that manufacturers may have. These figures exclude the construction and installation costs (WP6) in year 2018/19.		
We have already taken steps to mitigate this risk by issuing an RFI to manufacturers with an indicative quote and received two responses a note of interest from manufacturers. We plan to further mitigate this requesting an expression of interest from manufacturers at the prequalification process (beginning of WP5, March 2018). Based on responses to the RFI, we do not envisage a lack of response at this s however if this was to occur then the project may be halted prior to 2018.		RFI to onses and one ate this risk by e ed on this stage for to August	
	On review of the submitted plan and cost sheet, we propose to reduce the project spend at this potential stopping point by delaying the land purchas until a successful tenderer has been identified. The planning application requires official engagement with the land owner however land acquisition not required. The revised Total Cost at this point with land purchase delayed be $\pounds$ 714.95k (equivalent to $\pounds$ 602.56k of Outstanding Funding		o reduce the and purchase pplication l acquisition is rchase delayed nding

à	
	required). This equates to 4.21% of Total Costs (4.02% of the NIC Funding Request).
	Included in the existing and revised total spend figures is £30.31k of learning activities where knowledge obtained from the UPFC model development, equipment specification and lessons learned from the tendering process would be captured and disseminated to industry and academia through technical papers and presentation at the LCNI 2018 conference.

Project code	WPD/EN/NIC/04	Question Number	20
Question date	12/09/17	Answer date	14/09/17
Submission section question relates to	n/a		
Торіс	a) Enviro+consumer bens		
Question	Please confirm whether the Carbon Figures solely relate to CO2. If not, please list the other Greenhouse Gasses included within the figure.		
Notes on question			
Answer	The carbon figures quoted throughout the submission document are solely related to CO2. These figures have been calculated assuming that the capacity created by the UPFC is taken up by commercial solar PV (a zero carbon source of generation) and displaces other high-carbon sources of generation.		
	Other greenhouse gases that could be considered in the carbon figures for the UPFC project is the use of Sulphur Hexafluoride (SF6).		
	Our design includes 6 no. of 66kV or 132kV circuit breakers containing a volume of 10kg (216 l) or 59 kg (1374 l) of SF6 per circuit breaker, or equivalent to 228 to 1277 tonnes CO2, depending on the type of circuit breaker to be used. Typical leak rate is 0.5% a year although a leak rate of 0.1% has been claimed by one manufacturer. SF6-free equivalents are already installed in utilities for gaining experience under actual operational conditions.		
	As such, these figures of additional SF6 compared with our calculation of carbon carbon sources of generation.	b have a very small impand n saved by displacing ot	act when her high-
Attachments			

Question date       12/09/17       Answer date       14/09/         Submission section question relates to       N/A       Image: N/A       Image: N/A         Topic       a) Enviro+consumer bens       Image: N/A       Image: N/A         Question       Please could you also confirm how much Carbon is embedded with the technological solution?       Image: Notes on question         Answer       At this stage in the project we have not received detailed technical propu- from the manufacturers. In the absence of detailed technical data on th main components, there is little benefit in undertaking a detailed evaluat of embedded carbon.         To answer this question we have taken a qualitative view of the project a considered the potential embedded carbon of its main components. We concluded that, since the mass of the power electronic converters and H switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers. The main materials used in transformer construction are: <ul> <li>Steel (used for tank and magnetic core).</li> <li>Copper (used for windings).</li> <li>Mineral oil (used for insulation).</li> </ul> Image: Note and the semast is increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity.	Project code	WPD/EN/NIC/04	Question Number	21
Submission section question relates to       N/A         Topic       a) Enviro+consumer bens         Question       Please could you also confirm how much Carbon is embedded wit the technological solution?         Notes on question       At this stage in the project we have not received detailed technical proper from the manufacturers. In the absence of detailed technical data on th main components, there is little benefit in undertaking a detailed evaluat of embedded carbon.         To answer this question we have taken a qualitative view of the project a considered the potential embedded carbon of its main components. We concluded that, since the mass of the power electronic converters and H switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers. The main materials used in transformer construction are: <ul> <li>Steel (used for tank and magnetic core).</li> <li>Copper (used for windings).</li> <li>Mineral oil (used for insulation).</li> </ul> The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity.         As part of their 'Capacity to Customers' project. ENW commissioned a Ca	Question date	12/09/17	Answer date	14/09/17
Topica) Enviro+consumer bensQuestionPlease could you also confirm how much Carbon is embedded with the technological solution?Notes on questionAnswerAt this stage in the project we have not received detailed technical propor from the manufacturers. In the absence of detailed technical data on the main components, there is little benefit in undertaking a detailed evaluat of embedded carbon.To answer this question we have taken a qualitative view of the project at considered the potential embedded carbon of its main components. We concluded that, since the mass of the power electronic converters and H switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers.The main materials used in transformer construction are: • Steel (used for tank and magnetic core). • Copper (used for windings). • Mineral oil (used for insulation).The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity.As part of their 'Capacity to Customers' project. ENW commissioned a Ca part of the the 'Capacity to Customers' project.	Submission section question relates to	N/A		
Question       Please could you also confirm how much Carbon is embedded with the technological solution?         Notes on question       At this stage in the project we have not received detailed technical proper from the manufacturers. In the absence of detailed technical data on the main components, there is little benefit in undertaking a detailed evaluate of embedded carbon.         To answer this question we have taken a qualitative view of the project a considered the potential embedded carbon of its main components. We concluded that, since the mass of the power electronic converters and H switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers.         The main materials used in transformer construction are:       • Steel (used for tank and magnetic core).         • Steel (used for tank and magnetic core).       • Mineral oil (used for insulation).         The mass of all these materials increases with increasing power rating, two have sought to identify assessments of embedded carbon from units similar electrical capacity.         As part of their 'Capacity to Customers' project. ENW commissioned a Cababaa cabab	Торіс	a) Enviro+consumer bens		
Notes on question         Answer       At this stage in the project we have not received detailed technical proper from the manufacturers. In the absence of detailed technical data on the main components, there is little benefit in undertaking a detailed evaluate of embedded carbon.         To answer this question we have taken a qualitative view of the project a considered the potential embedded carbon of its main components. We concluded that, since the mass of the power electronic converters and H switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers.         The main materials used in transformer construction are:       • Steel (used for tank and magnetic core).         • Copper (used for windings).       • Mineral oil (used for insulation).         The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity.         As part of their 'Capacity to Customers' project. ENW commissioned a Carbon of the intervent of the series of the series of the intervent of the series of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity.	Question	Please could you also confirm how the technological solution?	much Carbon is embo	edded within
Answer       At this stage in the project we have not received detailed technical proportion of the manufacturers. In the absence of detailed technical data on the main components, there is little benefit in undertaking a detailed evaluation of embedded carbon.         To answer this question we have taken a qualitative view of the project a considered the potential embedded carbon of its main components. We concluded that, since the mass of the power electronic converters and H switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers.         The main materials used in transformer construction are: <ul> <li>Steel (used for tank and magnetic core).</li> <li>Copper (used for insulation).</li> <li>The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity.</li> </ul>	Notes on question			
To answer this question we have taken a qualitative view of the project a considered the potential embedded carbon of its main components. We concluded that, since the mass of the power electronic converters and H switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers. The main materials used in transformer construction are: • Steel (used for tank and magnetic core). • Copper (used for windings). • Mineral oil (used for insulation). The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity. As part of their 'Capacity to Customers' project. ENW commissioned a Ca	Answer	At this stage in the project we have not received detailed technical proposals from the manufacturers. In the absence of detailed technical data on the main components, there is little benefit in undertaking a detailed evaluation of embedded carbon.		
<ul> <li>The main materials used in transformer construction are:</li> <li>Steel (used for tank and magnetic core).</li> <li>Copper (used for windings).</li> <li>Mineral oil (used for insulation).</li> </ul> The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity. As part of their 'Capacity to Customers' project, ENW commissioned a Carbon from the communication of the communication of the communication of the customers' project.		<ul> <li>To answer this question we have taken a qualitative view of the project and considered the potential embedded carbon of its main components. We have concluded that, since the mass of the power electronic converters and HV switchgear is relatively small compared with the transformers, the main impact on embedded carbon will be the series and shunt transformers.</li> <li>The main materials used in transformer construction are: <ul> <li>Steel (used for tank and magnetic core).</li> <li>Copper (used for windings).</li> <li>Mineral oil (used for insulation).</li> </ul> </li> <li>The mass of all these materials increases with increasing power rating, thus we have sought to identify assessments of embedded carbon from units of a similar electrical capacity.</li> </ul>		
<ul> <li>Steel (used for tank and magnetic core).</li> <li>Copper (used for windings).</li> <li>Mineral oil (used for insulation).</li> </ul> The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity. As part of their 'Capacity to Customers' project, ENW commissioned a Carbon for the commission for the				
The mass of all these materials increases with increasing power rating, t we have sought to identify assessments of embedded carbon from units similar electrical capacity. As part of their 'Capacity to Customers' project, ENW commissioned a Ca				
As part of their 'Capacity to Customers' project, ENW commissioned a Ca				
Impact Assessment report from Tyndall Manchester. This work establish the following embedded carbon values for 132/11kV distribution transformers:	ioned a Carbon k established on			
Transformer Capacity			Transforn	her Capacity
23 MVA 38MVA			23 MVA	38MVA
Copper and Steel (tCO2e)57.075.8		Copper and Steel (tCO2e)	57.0	75.8
<b>Oil (tCO2e)</b> 8.50 15.6		Oil (tCO2e)	8.50	15.6
Transportation (tCO2e)         0.90         1.30		Transportation (tCO2e)	0.90	1.30
Total (tCO2e) 66.3 92.7		Total (tCO2e) 66.3 92.7		

	Based on these figures, we would make a preliminary estimate that the 25MVA rated shunt transformer for the UPFC would have a total embedded carbon of 72 tCO2e.
	The sizing of the series transformer will largely be based on the compensation rating (rather than its series rating) and again will be based on 25MVA. However, on the basis of the non-standard configuration, we would propose an estimate of 108 tCO2e for this unit (i.e. 50% more than the shunt unit).
	This gives a total estimate for the two transformers of 180 tonnes of CO2 equivalent (tCO2e. It should be noted that the carbon-intensive materials (steel, copper, oil) can largely be recycled at end of life.
	Assuming that the transformers represent 75% of the embedded carbon, we would make a preliminary estimate that the total embedded carbon in the UPFC will be 240 tCO2e.
	As such, these figures of embedded carbon have a very small impact when compared with our calculation of carbon saved by displacing other high-carbon sources of generation.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	22
Question date	12/09/17	Answer date	14/09/17
Submission section question relates to	n/a		
Торіс	g) Robust methodology/ready to implement		
Question	What risks are there to the delivery of the project/ the GB roll-out by issues relating to planning permission? How are you intending to mitigate these/ is there any budget assigned?		
Notes on question			
Answer	The primary risk is that planning permission is not achieved for the preferred site. The subsequent two main risks are that the process takes longer than scheduled due to additional conditions being imposed, and that additional surveys/stakeholder engagement is required, both delaying the securing of planning consent. All three risks are recorded in the project risk register (R012, R018, R019). The consequence for the project is a potential delay in issuing the Request for Quotation (RFQ) for firm prices from manufacturers, since this will rely on site information to complete the RFQ documentation. A delay is likely to impact installation and subsequent trial activity.		
	For roll-out the main risk at this time i installation on the network, with sites risk of not securing permission.	s identifying suitable site close to urban areas beii	es for UPFC ng at higher
	<ul> <li>The project risk mitigations are:</li> <li>1. The project site required for the application due to being below below 220kV.</li> <li>2. Two candidate sites have been planning refused at the other si</li> <li>3. An initial environmental review candidate site to eliminate any securing planning consent.</li> <li>4. Engagement with planning auth during project mobilisation, wit in the Communication Plan.</li> <li>5. The Mott MacDonald project tea and environmental specialist be preparing planning applications</li> </ul>	e UPFC requires a minor 1 hectare in size and for identified to provide and te. has been conducted for special conditions or like norities and stakeholders h actions and responsibil am includes a town plan oth with significant exper for UK sub-stations to a	planning operation option if each ely barriers to s will start lities identified ning specialist rience in advise and

	guide on specific local authority requirements and help address likely issues early.
	There is specific budget under Work Package 3 and Work Package 6 for both WPD and Mott MacDonald to specifically prepare and submit the outline and detailed planning application and engage with planning authorities.
	We have included contingency against WP3 (Studies) and WP6 (Construction and installation) and in each year to address the potential for delay in securing planning permission and additional work required.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	23
Question date	12/09/2017	Answer date	14/09/201 7
Submission section question relates to	n/a		
Торіс	b) Value for money		
Question	Please could you confirm whether your agreement with Mott Macdonald/ the provider of the UPFC technology will include any royalty mechanism to ensure GB Consumers receive good value for the trial?		
Notes on question			
Answer	*Marked as confidential*		
Attachments			

Project code	WPD/EN/NIC/04	Question Number	24
Question date	12/09/17	Answer date	14/09/17
Submission section question relates to	n/a		
Торіс	b) Value for money		
Question	Please outline how you have ensure Macdonald represents good value for balanced against the financial bene this solution abroad?	ed the contribution fr or money to GB consu fits on offer if they ca	om Mott umers when an market
Notes on question			
Answer	The primary responsibility for marketing the UPFC as a solution will lie with the manufacturer in competition with other manufacturers and other solutions.		n will lie with other
	Mott MacDonald recognise and hope that overseas network operators may continue to need support as they design and implement UPFCs following a further successful trial in the GB. Mott MacDonald will need to continue to win this advisory work through competitive tenders. Framework contracts which we currently have with overseas network operators will typically be re- let and competitively tendered over the timeframe of the HARP project.		
	As such, Mott MacDonald's discounts and contribution in-kind has not, up this point, been able to factor in a firm view of overseas revenues which i may earn.		nas not, up to ues which it
	Mott MacDonald has offered a package Appendix 10.8, pages 75-76 of our sub discounted rates which we have eviden rates at which we work with other clien add to this package the royalties arrang question 23 in order to address this point	of in-kind contributions mission. Part of this pac ced on 76 of our submis ts. We will within our re gement set out in our re int.	set out in ckage was the ssion alongside e-submission esponse to
Attachments			

Project code	WPD/EN/NIC/04	Question Number	25
Question date	12/09/17	Answer date	14/09/17
Submission section question relates to	n/a		
Торіс	a) Enviro+consumer bens		
Question	Within the Expert Panel bilateral yo environmental report for this soluti content of this report and whether interactions with the Environment A	ou referred to a deskt on - please provide d it identifies any requi Agency?	op etails on the ired
Notes on question			
Answer	*Marked as confidential*		

Project code	WPD/EN/NIC/04	Question Number	26
Question date	12/09/17	Answer date	14/09/17
Submission section question relates to	N/A		
Торіс	b) value for money		
Question	Please provide a comparison of the benefits offered by the UPFC compared to other similar alternative technologies.		
Notes on question			

Function		Capabilities	s with respect to this	function	
	UPFC	Quad Booster	Line/Cable	STATCOM	Commercial (ANM or DSR)
Re-direct power away from constrained sections of a ring	✓(fast acting and fine degree of line power flow control)	√(Control of line power flow)	*	-	<ul> <li>✓(subject to availability of flexible resources)</li> </ul>
Reduce "reverse" power being presented to Super- Grid Transformers on the transmission network	4	✓	<ul> <li>✓ (if it sufficiently alters power flows)</li> </ul>	-	✓
Re-direct power to avoid overloads in the event of a system fault or outage	✓(Fast acting in order of milliseconds)	<ul> <li>✓(Slow acting but acceptable)</li> </ul>	-	-	<ul> <li>✓(subject to availability of flexible resources)</li> </ul>
Control both real and reactive power flows	✓(Independent control of MW and MVAr)	<ul> <li>✓(MVA control only)</li> </ul>	-	-	-
Provide reactive power compensation	✓(Full MVAr output control)	-	-	√(Full MVAr output control)	To be trialled within NIC project Power Potential
Damping of voltage fluctuations	✓(Fast acting in order of milliseconds)	-	-	<ul> <li>✓ (Fast acting in order of milliseconds)</li> </ul>	To be trialled within NIC project Power Potential
No build solution	-	-	-	-	✓

Project code	WPD/EN/NIC/04	Question Number	27
Question date	12/09/17	Answer date	14/09/17
Submission section question relates to	n/a		
Торіс	c) Generates new knowledge		
Question	Please also provide written evidence amongst other network licensees to network if it is proven to be success	e to show there is ar o use this solution on sful	n appetite their
Notes on question			
Answer	Please find attached letters of support f associations. We will include any furthe submission.	rom other licencees or r letters of support in o	trade ur re-
Attachments	"Letter of support WPD 140917" "WPD HARP project – 14 09 17" "Unified Power Flow Controller"		

Project code	WPD/EN/NIC/04	Question Number	28
Question date	14/09/17	Answer date	19/09/17
Submission section question relates to	Section 9		
Торіс	Multiple		
Question	The design of the UPFC is an import Please provide a justification that t funding associated with deliverable	tant output from the phe proposed percentate one is appropriate.	project. age of
Notes on question			
Answer	In the first instance, the NIC Funding Request percentages have been aligned to the level of expenditure for each Project Deliverable. The Total Costs associated with achieving Project Deliverable 1 (Project design and study information for installation & commissioning) is £510.14k, this equates to 3% of the Total Costs for the project. The NIC Funding Request at this stage is £471.99k, this equates to 3.15% of the total NIC Funding Request. The 'Design documentation' deliverable in milestone 1 will consist of the design work achieved in developing the UPFC model for network modelling and defining its specification for suppliers at the tender stage, this is a preliminary design prior to the successful manufacturer carrying out the detailed design. The design of the UPFC will be progressively refined during the tendering process, during the contractor design period (line 140 in our project plan), during detailed design reviews (line 128/129 in our project plan) and later in the trials period. The refined model at the end of the project will be incorporated into the DNO Toolset to be delivered as part of Project Deliverable 10.		
	project and these activities will be spread Project Deliverable 1 will also include the Communications Plan which will set out project, how this learning will be capture stakeholders/beneficiaries of this learning learning will be captured.	ad across Deliverables 1 ne Knowledge Managem the planned learning th red and disseminated, w ng are and how any unp	.,2,3,9 and 10. ent and proughout the ho the planned
Attachments			

Project code	WPD/EN/NIC/04	Question Number	29
Question date	14/09/17	Answer date	19/09/17
Submission section question relates to	Section 9		
Торіс	Multiple		
Question	Please explain what is innovative a associated with project deliverable that the proposed percentage of fu deliverable is appropriate.	nd what new learning two. Please provide a nding associated with	ı is a justification ı this
Notes on question			
Answer	The learning and innovation associated with Project Deliverable 2 (Tender process completed with supplier under contract) is detailed in Table 5.1 of the submission document. The evidence for this deliverable is the Tender documentation and Agreed contract. The Tender documentation will include the Tender assessment report and the Tender evaluation report. These reports will include a summary of the manufacturers' anonymised submissions covering their scope of work, equipment specifications, detailed costs and delivery programme. The Agreed contract will provide detail on the agreed performance bonds, milestones and liquidated damages and a summary will be made available to other DNOs excluding any commercially sensitive information. Both the Tender documentation and Agreed contract will contain valuable information and learning from the design and tendering stage of a UPFC project. The UPFC will be a first-of-a-kind project in the UK therefore learning and innovation at this stage of the project will also be realised from the modellin procedures and techniques used to develop the UPFC in the detailed design period, the methodology for site selection and the work associated with outlining the planning application for the UPFC project. The proposed percentage of NIC Funding Request associated with Project Deliverable 2 is 12%. This has been aligned to the expenditure in financial year 2018/19 which equates to £2,042k (12% of Total Costs). These costs include the work associated with the tender assessment, selecting a preferred supplier for contract award and a 10% up front payment to the preferred supplier which we will aim to protect through performance bonds. Based on the work required to achieve the milestone deliverables and the learning to be obtained at this stage of the project we beliver 12% of NIC Funding Request for Project Deliverable 2 is appropriate.		2 (Tender Fable 5.1 of the Tender on will include t. These sed ions, detailed de detail on ages and a commercially eed contract and tendering tailed design ated with with Project e in financial These costs ting a nent to the nance bonds. les and the 12% of NIC

Project code	WPD/EN/NIC/04	Question Number	30
Question date	14/09/17	Answer date	19/09/17
Submission section question relates to	Section 9		
Торіс	Multiple		
Question	The proposed funding allocated to given these are business as usual p when commissioning new equipme project learning. Please provide a j percentage of funding associated w	Project Deliverable 3 processes that are und nt and are not directly ustification that the p with this deliverable is	appears high lertaken y linked to roposed appropriate.
Notes on question			
Answer	The percentage of NIC Funding Request for Project Deliverable 3 is 60% and has a deadline of 31/08/20. The evidence for Project Deliverable 3 is the Factory Acceptance Test (FAT) report, Site Installation report and Site Acceptance Test (SAT). The proposed percentage of 60% is aligned to the costs associated with Work Packages (WP) WP5 (Procurement) and WP6 (Construction & Installation) incurred in financial year 2019/20, this equates £10,860k or 64% of the Total Costs. These costs include the manufacturing and shipping fees for the UPFC, site preparation costs and third party civil and structural works. It does not include the commissioning costs that will be incurred in financial year 2020/21 to achieve the SAT report.		3 is 60% and ole 3 is the nd Site igned to the and WP6 , this equates nanufacturing I party civil osts that will
	The Total Costs to achieve Project Deliv Request at this stage of the project, as WPD taking on a level of risk and comn	verable 3 exceed the NIG such this shows Mott M nitment to the project.	C Funding acDonald and
	In order to reach the FAT and SAT reports, we will have created and set the methodologies for the testing procedures of the UPFC, the performance requirements to be met and the verification of the devices performance. The site installation report will include the manufacturers design review reports, the detailed planning application and site survey reports, all of which will provide substantial learning for the manufacturing, construction and installation of a UPFC.		
	A detailed trials strategy report and tria will be developed during this phase of t included as evidence for Project Deliver another vital part of learning on the pro documents as evidence for Project Deliver	als instruction document the project. These have rable 3 however we belic oject and propose to inc verable 3 in the re-subn	for the UPFC not been eve this is ude both hission.

Project code	WPD/EN/NIC/04	Question Number	31
Question date	14/09/17	Answer date	19/09/17
Submission section question relates to	Section 9		
Торіс	Multiple		
Question	Project deliverables 4-10 appear to of the project and the learning that justification that the proposed perc with these deliverables is appropria	be associated with t will be shared. Pleas entage of funding ass ate.	he outputs se provide a sociated
Notes on question			
Answer	The total percentage of NIC Funding Re through to 10 is 25%.	equest for Project Delive	erables 4
	Prior to commissioning, the project expenditure exceeds the level of NIC Funding Request as stated in our response to Question 30. The project expenditure after commissioning and prior to Work Package 9 (Trial execution) is 94.3% of the Total Costs (£15,995k) with only 77% of NIC Funding Request received (£11,519.2k). This was intentional and provides an incentive to Mott MacDonald and WPD to deliver the project in full. The costs associated with achieving Project Deliverables 4,5,6,7,9 and 10 equate to 5.7% of the Total Costs against 23% of NIC Funding Request remaining therefore the proposed percentages against the Deliverables is more aligned to the amount of learning to be obtained rather than the associated expenditure. At this stage of the project, Deliverable 8 with 2% of NIC Funding Request is already achieved.		vel of NIC e project (Trial 7% of NIC and provides : in full.
			7,9 and 10 Request verables is han the le 8 with 2%
	The NIC Funding request for Project Deliverable 4 (Trials Report 1) is 5% with Trials Report 2, 3 and 4 (Deliverables 5, 6 and 7) requesting 4%. The Trials Reports will provide valuable learning for the deployment of the UPFC, its setup and configuration and analysis of its performance against set objectives. This equates to a total NIC Funding Request of 17% for the Trails Reports.		
	The remaining percentage of NIC Fundi distributed across Project Deliverables learning outcomes of each milestone. Deliverable 8) requests 2%, the dynam response to network issues/voltage dis	ng Request is 8% and h 8, 9 and 10 in proportio The Replicability report ic model and report of f turbances (Project Deliv	nas been for n with the (Project findings in verable 9)

	requests 3% and the DNO Toolset including demonstration and summary report (Project Deliverable 10) requests 3%.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	32								
Question date	21/09/2017	Answer date	25/09/201 7								
Submission section question relates to	N/A										
Торіс	b) Value for money										
Question	Please explain in more detail (with royalty arrangements proposed cor Governance Document.	reasons) how you th nply with Chapter 10	ink the of the								
Notes on question											
Answer	Our response on royalties concerned bo MacDonald.	oth the manufacturer ar	nd Mott								
	Manufacturer	Manufacturer									
	We did not make a commitment to a royalties arrangement as a pre- condition within our Request for Information (RFI) issued to manufacturers or test their appetite around royalties. We did ensure that respondees stated that they had read and agreed to comply with the intellectual property provisions of the NIC. We will test at the tender stage the manufacturers' proposals to protect GB customers both at delivery and around future revenues and this may include an offer from manufacturers in the form of a royalties arrangement.										
	Mott MacDonald										
	For clarity, Mott MacDonald is a person occasionally sell access to IT platforms otherwise no products which we sell.	-hours driven business; which we have develop	whilst we ed, there are								
	As such, there are no Commercial Prod	ucts.									
	The Background IPR consists, among other items, of a simulation model which we developed. We have made clear on page 34 of our submission the we will make this available as part of our dissemination to other GB DNOs. This will be free of charge and therefore we count the engineering time associated with this on page 75 as part of Mott MacDonald's financial contribution to the project.										
	The Foreground IPR and the Relevant F the form of written reports, specification	Foreground IPR will be cons, calculations or simu	ontained in Ilations,								

	commercial pricing information, schedule information (i.e. how long things took to build), and in the form of the know-how of Mott MacDonald staff.
	We currently envisage with Western Power Distribution to carry out public dissemination and which goes beyond the minimum requirements in clause 9.13 of the NIC Governance Document. Relevant Foreground IPR will in most cases be available beyond other Network Licensees, and available to the supply chain, other manufacturers, other consultants and overseas DNOs. The only effective alternative mechanism would be to run smaller dissemination events only open to the Network Licensees and to attempt to charge other entities for copies of reports and documents. Judging from other precedents (such as Energy Networks Association (ENA) documents and the Strategic Technology Programme (STP) which ran for a number of years under the Innovation Funding Incentive) the price at which these can be sold is relatively low, of the order of tens or low hundreds of pounds.
	Our royalties mechanism is intended to therefore provide a return for GB customers on the know-how of Mott MacDonald staff, since this is likely to the determining factor by which we earn overseas revenues on other UPFC projects. That know-how will only reasonably be exploited on dedicated UPFC projects rather than wide-ranging optioneering or feasibility studies considering many options. We have made a number of reasonable exclusions or caveats to protect against, for example, not being paid by the client and fluctuations in exchange rates. If these are not enacted, we realistically have to price for these items within our price to the client at the outset, reducing the likelihood of winning the work at all and generating any revenues for GB customers.
	As such our proposal complies with Section 10 of the NIC Governance document as follows:
	<ol> <li>Mott MacDonald will pay royalties to WPD on receipt of the final payment from the client on a UPFC project which meets the criteria set out in question 23. This will occur throughout the year.</li> <li>WPD will at the end of the year collate the royalties which it has received from Mott MacDonald.</li> <li>This equates to RRk,y in paragraph 10.6 where y refers to WPD and k to the current year.</li> <li>WPD will deduct Directly Attributable costs, if applicable, and report the net value to the Authority.</li> </ol>
	<ol> <li>5. NLCCk, NLECk, and RAk will be the values from the Licence Direction for HARP, if awarded.</li> <li>6. The Authority will carry out the calculation in paragraph 10.6 in order</li> </ol>
	to derive APk,y and instruct WPD to return this amount to consumers by means of the NIC Funding Direction.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	33						
Question date	21/09/2017	Answer date	25/09/201 7						
Submission section question relates to	Appendices								
Торіс	a) Enviro+consumer bens								
Question	Please comment on the carbon ben current business-as-usual approach those of the proposed method (440	efits of capacity relea nes and their compari 0,000 tCO2e by 2040)	ised with son with						
	Please clarify which scenario from estimate of carbon benefits.	FES was used to deriv	/e the						
Notes on question									
Answer	These figures have been calculated assuming that the capacity created by the UPFC is taken up by commercial solar PV (a zero carbon source of generation) and displaces other high-carbon sources of generation. We confirmed in our answer to question 20 that carbon, and this way of offsetting carbon used in power generation, was the only factor in our carbon benefits calculation.								
	We clarified in our response to question reinforcement of lines and/or cables cre purchased in large quantities, some of capacity.	15 that business-as-us ates more capacity; bu which may in fact be str	sual t can only be randed						
	Because we had no firm assumption that of capacity which might be unused or "so the capacity created by conventional re	at we could provide for s stranded", we did not di inforcement.	the proportion iscount any of						
	In the same way, if all of the capacity which it creates is indeed used by ne renewable generation and not stranded, conventional reinforcement can save more carbon than the 440,000 tCO2e by 2040 calculated for our Method.								
	It is important context that if renewables are put off from constructing due to high grid connection costs, then no carbon is offset or saved at all. This has already been the experience for some periods of time, on some parts of the GB distribution network. This is the driving motivation to find alternative means to release capacity on the network with devices such as the UFPC.								

	We used the "Slow Progression" scenario from the Future Energy Scenarios (FES) as the source of grid carbon intensitity which could be offset by renewables.
Attachments	

Project code	WPD/EN/NIC/04	Question Number	34							
Question date	05/10/2017	Answer date	10/10/201 7							
Submission section question relates to	n/a									
Торіс	Multiple									
Question	In various responses to the Q&A the use of quadrature boosters (QBs) as the counterfactual have been explored, either alone or in combination with other devices depending on the constraint being relieved. Together with the clarification that QBs are available at 132kV and based on relieving (real) constraints currently considered present on the 132kV and 66kV systems (please justify whether the "fast" response of UPFCs are required), do your original CBA and NPV calculations still hold? If not can you please revise your estimates.									
Notes on question										
Answer	<ul> <li>We will distinguish between responses</li> <li>1. Throughout the day, and from a one half hour to the next</li> <li>2. Over the timescale of a few min</li> <li>3. Over the timescale of sub-seco</li> <li>The first of these is typically experience where the system is intact but system variations in renewable output, or due the day leading to different requirement illustrated by Table 2.1 on page 12 of c</li> <li>The second of these is typically experience distribution network and can be utilised circuits.</li> <li>The third of these is typically experience</li> </ul>	which are required: day-to-day, but not fast nutes up to 30 minutes nd through to several se ed during a "normal run requirements may be ch to changes in power fac its for reactive power. T our submission. enced following a fault ou it to relieve post-fault ou	er than from econds. ning" situation nanging due to ttor throughout this was n the verloading of							
	The third of these is typically experienced following a fault on the transmission network (including outages of large transmission-connec generators) and/or distribution network which has caused a temporary voltage disturbance and is used to mitigate this disturbance.									
	We will compare the functions of the Un and a quadrature booster in each case.	nified Power Flow Contr	oller (UPFC)							
	Variations throughout the day and	from day-to-day								
	There is little difference between the ca a UPFC to adjust power flow on a 132k	apabilities of a quadratu V or 66kV ring on these	re booster and timescales.							

Whilst the quadrature booster is based upon a mechanical tap changer which may take several minutes to make multiple taps, it is able to act sufficiently fast to maintain overhead lines and other network equipment within their ratings when the system is intact and continues to have redundancy.

#### Over the timescales of a few minutes

Each of our case studies discussed in the Full Submission at Evesham and at Walpole concerned rings on the 132kV or 66kV network formed of overhead lines (at Walpole) or both overhead lines and cable (at Evesham).

The convention amongst the UK Distribution Network Operators (DNOs) is that distributed generation is able to be accommodated to the full (duplicate) capacity of the circuit. In the case of rings, this means that generation can be added to the extent that both directions around the ring are fully loaded. In the case of demand, each side of the ring is only loaded to half of its capacity to ensure that demand can be fed from the other side of the ring in the event of a fault.

As such, the capacity of the overhead lines forming the ring or parts of the ring directly impact:

- 1. The amount of distributed generation that would potentially have to be removed (tripped) following a fault on the ring;
- 2. The amount of demand which can be supported by the ring.

Overhead lines when fully loaded heat up over a timeframe of tens of minutes, during which they expand and sag, meaning that they are closer to the ground. For the rare occasions on which a fault occurs, a level of risk that the weather is also adverse and preventing the line from cooling, and that a sufficiently tall vehicle, or a person carrying implements, is passing underneath and could come close enough to the (now lower hanging) line to cause a flash-over is agreed in the industry to be acceptable.

Western Power Distribution is thus able to operate 132kV and 66kV overhead lines with a higher capacity or "rating" following a fault. In the case of a typical construction (175mm<sup>2</sup> Lynx ACSR) operating in the summer, this rating is 7% higher than the intact rating and is 465A. Western Power Distribution stipulate the additional load on the line should be reduced "as soon as practicable" and in any circumstance within 24hours. This is documented within the Company Directive "Standard Technique SD8A/2: Relating to revision of overhead line ratings", and goes some way to minimising the amount of generation which would have to be removed, and increasing the amount of demand which can be supported.

National Grid (the transmission operator) go one step further and point out that if the line is not running at full capacity prior to the fault, it is therefore not operating at its full design temperature. It will therefore take longer before the heating effect has caused the line to sag. This is documented in Technical Guidance Note TGN(E) 26 "Current ratings for overhead lines".

To give an example from this document, the same conductor  $(1x175mm^2$  Lynx operating at 132kV) line will have a post-fault continuous rating which of 465A, identical to the WPD calculation. Loads of up to 625A can be place upon the line if the line was running at only 84% of its original capacity

before the fault, and if the load can be certain to be removed within 3 mins. Loads of up to 495A can be placed upon the line if the load can only be certain to be removed within 10 mins. Loads up to 470A can be placed upon the line if the load can only be certain to be removed within 20 mins.

A quadrature booster, even with automated control, cannot guarantee to operate within 3 minutes, since the number of taps required will depend on the tap setting in which the device finds itself when the fault occurs. As such it is likely to be limited to a 10 minute rating. A quadrature booster without automated control and relying on manual control via SCADA from the control room could only be expected to operate within 20 mins.

A UPFC could be guaranteed to operate within 3mins. It therefore is able to support greater amounts of renewable generation and demand, knowing that a fast-acting method is available to reduced load on overhead lines following a fault and ensuring that the line can be brought back within its post-fault continuous rating. In the example above, the difference between a 3 minute rating of 625A and a 10 minute rating of 495A is equivalent to 30MVA of generation or demand which can be supported.

The cable sections within a ring will have a slower thermal time constant and as such are unlikely to benefit in the same way. The exception is where cables have been deliberately designed to run closer to their maximum load during normal operation than the associated overhead lines on the ring, in which case their time to reach critical temperature may also need to be considered.

## Variations over the timescale of sub-second through to several seconds

National Grid in their 2017 System Operability Framework (Section 4.5.3) describe the action which we intend for the UPFC to provide:

"The retained voltage during a fault affects the ability of a generator to ride through the disturbance. It is supported by fast fault current injection (FFCI), reactive current which arrests the voltage dip during a disturbance. This helps to reduce the risk of generation failing to ride through a fault and also facilitates protection operation. Currently, synchronous generators are the predominant source of fast fault current injection due to their characteristic immediate fault current injection."

The SOF also identifies that generation technologies dependent on PLL controllers, such as wind and PV, are more vulnerable to voltage disturbance than conventional synchronous machines. With less conventional plant to control disturbances and increasing reliance on embedded wind/PV, the ability to manage transient events to avoid cascade tripping will be critical.

Because a quadrature booster is controlled mechanically, and because its controllable element is in series rather than parallel, it is not able to provide the fast fault current injection described by National Grid over the timescale of sub-second through to several seconds.

Only the addition of a STATCOM would achieve this function.

	It is interesting to note that several academic papers ([1][2]) show that a UPFC is able to provide a higher contribution to voltage stability than a STATCOM by reducing the amplitude of voltage variations faster or by increasing the voltage stability margin. The HARP project will allow this effect to be investigated further and practically demonstrated.
	Conclusion
	Our NPV calculations were based on case studies at Evesham and Walpole and which benefit not only from managing power flow variations throughout the day and from day-to-day but also from managing variations over several minutes post-fault. Since the UPFC provides better performance in the latter case, and can provide value-adding services equivalent if not better than a STATCOM, we continue to believe that a quadrature booster is not a reasonable comparison.
	We have selected conventional reinforcement as the alternative which creates sufficient capacity as to wholly remove the concerns about capacity over the timescales of a few minutes following a fault, and to wholly remove concerns about capacity in the intact state. We have not at this stage included in our NPV calculation, or relied upon, income from providing fast fault current injection to National Grid when making our business case but will seek to demonstrate the technical capability to deliver this service.
	<ul> <li>[1] "Effects of STATCOM, TCSC, SSSC and UPFC on static voltage stability",</li> <li>M.A. Kamarposhti &amp; H. Lesani, Electrical Engineering, Volume 93, pages 33- 42, 2011</li> </ul>
	[2] "Unified Power Flow Controller in Alleviation of Voltage Stability Problem", N. Dizdarević, Doctoral Thesis, University of Zagreb, 2001
Attachments	

Project code	WPD/EN/NIC/04	Question Number	35						
Question date	05/10/2017	Answer date	10/10/201 7						
Submission section question relates to	N/A								
Торіс	Multiple								
Question	During the 2nd Bi-lateral Meeting your notes) showing the networks UPFCs may be the best solution to you please clarify how many UPFC For example, in the Cardiff East – A needed but the table suggests two	you presented a table in the WPD licence a relieve network cons s per network (GSP) a Aberthaw network on	(page 6 of reas where traints. Can are required. ly one may be						
Notes on question									
Answer	In the bid we identified several areas of Grid Supply Point (GSP) networks within WPD's four licence areas that were stressed and in which a UPFC could be used. Some of these GSP networks run in parallel therefore in some cases only a single UPFC can be used to alleviate on the interconnected network if the constraint being managed is related to the power flow between the GSPs. In some cases there are meshed networks in parallel running GSP groups where they do not straddle the GSPs; in this case multiple UPFCs would be needed, although in the cases we have identified this is not the case								
	Please see below for the number of UPFCs required in the GSP networks we identified in the bid.								
	<b>West Midlands (total of 2)</b> Feckenham – 1 UPFC Shrewsbury – 1 UPFC								
	East Midlands (total of 1) Walpole – 1 UPFC								
	<b>South Wales (total of 2)</b> Pembroke – 1 UPFC Swansea North – 1 UPFC								
	South West (total of 4) Indian Queens/Alverdicott group – 1 UPFC Bridgewater (runs in parallel with Taunton) – 1 UPFC Abham/Landulph/Exeter group – 2 UPFCs								
	We have therefore revised 11 sites in	WPD down to 9.							

	We do not believe that this change is material and, as such, we continue to see a roll-out potential of 23 sites.
Attachments	

Intervention	After Diversity Peak reduction (kW)	Gross Peak Reduction (kW)	Assumed running hours/year	kWh/year reduction	£/kW price redu	/h benefit (retail electricity if we are considering the ction on customer energy bills)	£/ yea benefit custom energy b	ar (on 1er oills)	$\pounds/kWh$ benefit (40% of retail electricity price [i.e. the cost of generating electricity] if we are considering the avoided cost of generation)	£/ year benefit (avoided cos of generatior	Life of measure years (applianc life)	e li ie	E benefit over fe of measure (on customer energy bills)	£ benefit over life of measure (avoided cost o generaiton)	e f (	Cost of measure Appliance cost)(£)	£/year saving in distribution UoS costs	£/year savings in DNO's network reinforcement costs (from deployment of EE measure)	£/ye DN reinfo (over	ar savings in O's network rcement costs · lifetime of EE measure)
Appliances	0.14	0.212	627	133	£	0.14	£ 19	9.11	£ 0.057	£ 7.6	4 10	£	191.12	£ 76.45	£	345.00	£ 1.91	£ 1,858.00	£	186.00
Heating	0.385	0.453	542	983	£	0.14	£ 14:	1.26	£ 0.057	£ 56.5	0 20	£	2,825.14	£ 1,130.06	5 £	750.00	£ 14.13	£ 5,110.00	£	255.00
Lighting	0.27	0.54	185	100	£	0.14	£ 14	4.37	£ 0.057	£ 5.7	5 30	£	431.10	£ 172.44	1 £	50.00	£ 1.44	£ 3,583.00	£	119.00
Behaviour	0.072	0.085	N/A	50	£	0.14	£	7.19	£ 0.057	£ 2.8	7 5	£	35.93	£ 14.37	£	70.00	£ 0.72	£ 956.00	£	191.00
Solar PV	18.75	37.5	425	15938	£	0.14	£ 2,290	0.22	£ 0.057	£ 916.0	9 30	£	-	£ 27,482.63	3 £	23,756.25	£ 229.02	£ 610,000.00	£	20,333.33
Combined Measures	0.357	0.51	549	280	£	0.14	£ 40	0.24	£ 0.057	£ 16.0	9 10	£	402.36	£ 160.94	1 £	425.00	£ 4.02	£ 4,738.00	£	474.00